



# FIRE EQUIPMENT SERVICES

PO Box 3070, Nunawading, Vic 3131  
www.fes.com.au e: service@fes.com.au

ABN 28 598 558 561  
Tel 1300 855 163  
Fax 1300 655 511



## ESSENTIAL SAFETY MEASURES SERVICE REPORT

The Level of Performance and Frequency of Maintenance is as required by Essential Safety Measures Requirements

Service Visit: **XXX**  
Completed Date: **XX/XX/2022**  
Site Details: **XXX**

### SAMPLE REPORT

Work Performed By: XXX

Purchase Order: **PO# SAMPLE**

### IMPORTANT NOTICE

On servicing this site we determined the item(s) listed below require your attention.

Please contact FES for further assistance

Equipment Serviced With Comments			Location	Defect/Comment:
0000845320	CO280	CO2 EXTG 5KG	8C, LMR, UP STAIRS	L4 PRESSURE TEST IS OVERDUE, ,
0000115693	CO280	CO2 EXTG 5KG	8C, LMR, (MAIN)	L4 PRESSURE TEST IS OVERDUE, ,
0000115692	CO280	CO2 EXTG 5KG	8C, LMR, (MAIN)	L4 PRESSURE TEST IS OVERDUE, ,
0000574449	CO190	CO2 EXTG 3.5KG	2C, I.T. W/SHOP, COMPUTER RM	L4 PRESSURE TEST IS OVERDUE, ,
0000888232	CO190	CO2 EXTG 3.5KG	2C, IT, ENTRY	L4 PRESSURE TEST IS OVERDUE, ,
0000915151	HR000	HOSE REEL	BASE (W), NEW BLDG, BOTTM OF C/DOOR	REEL DAMAGED, NEEDS TO BE REPAIRED (BY ON SITE STAFF) OR REPLACED., ,
0000915154	HR000	HOSE REEL	BASE (W), NEW BLDG, TOP OF RAMP	POOR ACCESS - ACCESS TO EQUIPMENT MUST BE IMPROVED, ,
0003210543	CO190	CO2 EXTG 3.5KG	7W, NEW BLDG, EAST EXIT	L4 PRESSURE TEST OVERDUE, ,
0003136960	DA250	DP ABE EXTG 4.5KG	7W, LAB AT SLIDER, WALL (RECESSED)	L4 PRESSURE TEST OVERDUE, ,
0003136962	DA250	DP ABE EXTG 4.5KG	7W, NEW BLDG, ECOLI W7.54	L4 PRESSURE TEST OVERDUE, ,
0003136963	DA250	DP ABE EXTG 4.5KG	7W, NEW BLDG, C.RM W7.56	L4 PRESSURE TEST OVERDUE, ,
0003060785	CO190	CO2 EXTG 3.5KG	7W, NEW BLDG, MED CHEM W7.83	L4 PRESSURE TEST OVERDUE, ,
0000915121	CO190	CO2 EXTG 3.5KG	7W, NEW BLDG, WEST EXIT	L4 PRESSURE TEST OVERDUE, ,
0003136961	DA250	DP ABE EXTG 4.5KG	7W, NEW BLDG, WALL (RECESSED)	L4 PRESSURE TEST OVERDUE, ,
0003137000	DA460	DP ABE EXTG 9KG	7W, NEW BLDG, W7.87	L4 PRESSURE TEST OVERDUE, ,
0000915118	CO190	CO2 EXTG 3.5KG	7W, NEW BLDG, WALL (RECESSED)	L4 PRESSURE TEST OVERDUE, ,
0000915117	CO190	CO2 EXTG 3.5KG	7W, NEW BLDG, WALL (RECESSED)	L4 PRESSURE TEST OVERDUE, ,
0000915116	CO190	CO2 EXTG 3.5KG	7W, NEW BLDG, WALL (RECESSED)	L4 PRESSURE TEST OVERDUE, ,
0003136967	DA250	DP ABE EXTG 4.5KG	7W, NEW BLDG OFFICE, EAST ENTRY	L4 PRESSURE TEST OVERDUE, ,
0003136959	DA250	DP ABE EXTG 4.5KG	7W, NEW BLDG OFFICE, DIRECTORATE	L4 PRESSURE TEST OVERDUE, ,
0000915112	CO190	CO2 EXTG 3.5KG	7W, NEW BLDG OFFICE, DIRECTORATE KIT	L4 PRESSURE TEST OVERDUE, ,
0003136966	DA130	DP ABE EXTG 2.5KG	7W, NEW BLDG OFFICE, GREEN -RECESSED	L4 PRESSURE TEST OVERDUE, ,
0003136945	DA130	DP ABE EXTG 2.5KG	7W, NEW BLDG OFFICE, GREEN- RECESSED	L4 PRESSURE TEST OVERDUE, ,
0003136956	DA250	DP ABE EXTG 4.5KG	6W, NEW BLDG, LIFT FOYER	L4 PRESSURE TEST OVERDUE, ,
0000915104	CO190	CO2 EXTG 3.5KG	6W, NEW BLDG, EAST ENTRY	L4 PRESSURE TEST OVERDUE, ,
0003136997	DA460	DP ABE EXTG 9KG	6W, NEW BLDG, PLANT ROOM 3	L4 PRESSURE TEST OVERDUE, ,
0000915102	CO190	CO2 EXTG 3.5KG	6W, NEW BLDG, WALL (RECESSED)	L4 PRESSURE TEST OVERDUE, ,

SV no: XXXX  
Printed: XX/XX/2022

Maintenance performed in accordance with AS 1851 - 2005  
Hose Reel(s) without water flow defects listed above are deemed to have PASSED - with a minimum flow of  
20 l/min (for 19mm hose) or 25 l/min (for 25mm hose) in accordance with the BCA & AS1851

a division of





# FIRE EQUIPMENT SERVICES

PO Box 3070, Nunawading, Vic 3131  
www.fes.com.au e: service@fes.com.au

ABN 28 598 558 561  
Tel 1300 855 163  
Fax 1300 655 511



## ESSENTIAL SAFETY MEASURES SERVICE REPORT

The Level of Performance and Frequency of Maintenance is as required by Essential Safety Measures Requirements

Service Visit: **XXX**  
Completed Date: **XX/XX/2022**  
Site Details: **XXX**

### SAMPLE REPORT

Work Performed By: **XXX**

Purchase Order: **PO# XXXX**

0000915100	CO190	CO2 EXTG 3.5KG	6W, NEW BLDG, EQUIP RM W6.79	L4 PRESSURE TEST OVERDUE, ,
0003136952	DA250	DP ABE EXTG 4.5KG	6W, NEW BLDG, COLDROOM 2A	L4 PRESSURE TEST OVERDUE. NEEDS MOUNTING, ,
0000915098	CO190	CO2 EXTG 3.5KG	6W, NEW BLDG, COLDROOM 2A	L4 PRESSURE TEST OVERDUE, ,
0003060742	CO190	CO2 EXTG 3.5KG	6W, NEW BLDG, WALL (RECESSED)	L4 PRESSURE TEST OVERDUE, ,
0003136951	DA250	DP ABE EXTG 4.5KG	6W, NEW BLDG, WEST EXIT	L4 PRESSURE TEST OVERDUE, ,
0003136994	DA460	DP ABE EXTG 9KG	6W, NEW BLDG, PLANT ROOM 2	L4 PRESSURE TEST OVERDUE, ,
0000915093	CO190	CO2 EXTG 3.5KG	6W, NEW BLDG, WALL (RECESSED)	L4 PRESSURE TEST OVERDUE, ,
0003136947	DA130	DP ABE EXTG 2.5KG	6W, NEW BLDG OFFICE, EAST LOUNGE	L4 PRESSURE TEST OVERDUE, ,
0003136955	DA250	DP ABE EXTG 4.5KG	6W, NEW BLDG OFFICE, W6.11	L4 PRESSURE TEST OVERDUE, ,
0003136949	DA130	DP ABE EXTG 2.5KG	6W, NEW BLDG OFFICE, GREEN RECESSED	L4 PRESSURE TEST OVERDUE, ,
0003136999	DA460	DP ABE EXTG 9KG	6W, NEW BLDG OFFICE, PLANT RM WP6.40	LOW ON PRESSURE, NEEDS REPLACEMENT, ,
0003136946	DA130	DP ABE EXTG 2.5KG	6W, NEW BLDG OFFICE, WALL (RECESSED)	L4 PRESSURE TEST OVERDUE, ,
0000915085	CO190	CO2 EXTG 3.5KG	5W, NEW BLDG, EAST ENTRY	L4 PRESSURE TEST OVERDUE, ,
0003136992	DA460	DP ABE EXTG 9KG	5W, NEW BLDG, PLANT ROOM 3	L4 PRESSURE TEST OVERDUE, ,
0003060734	CO190	CO2 EXTG 3.5KG	5W, NEW BLDG, WALL (RECESSED)	L4 PRESSURE TEST OVERDUE, ,
0003136943	DA250	DP ABE EXTG 4.5KG	5W, NEW BLDG, WALL (RECESSED)	PRESSURE LOW, NEEDS REPLACING, ,
0003136942	DA250	DP ABE EXTG 4.5KG	5W, NEW BLDG, GEL RM W5.55	L4 PRESSURE TEST OVERDUE, ,
0000915078	CO190	CO2 EXTG 3.5KG	5W, NEW BLDG, GEL RM W5.55	L4 PRESSURE TEST OVERDUE, ,
0000915077	CO190	CO2 EXTG 3.5KG	5W, NEW BLDG, WALL (RECESSED)	L4 PRESSURE TEST OVERDUE, ,
0003136940	DA250	DP ABE EXTG 4.5KG	5W, NEW BLDG, WEST EXIT	L4 PRESSURE TEST OVERDUE, ,
0003136991	DA460	DP ABE EXTG 9KG	5W, NEW BLDG, PLANT RM WP5.88	L4 PRESSURE TEST OVERDUE, ,
0000915073	CO190	CO2 EXTG 3.5KG	5W, NEW BLDG, MIDDLE LAB	L4 PRESSURE TEST OVERDUE, ,
0000915072	CO190	CO2 EXTG 3.5KG	5W, NEW BLDG, MIDDLE LAB	L4 PRESSURE TEST OVERDUE, ,
0000915071	CO190	CO2 EXTG 3.5KG	5W, NEW BLDG, N/E LAB CORNER	L4 PRESSURE TEST OVERDUE, ,
0003136936	DA130	DP ABE EXTG 2.5KG	5W, NEW BLDG OFFICE, EAST ENTRY	L4 PRESSURE TEST OVERDUE, ,
0003136941	DA250	DP ABE EXTG 4.5KG	5W, NEW BLDG OFFICE, OPPOSITE W5.11	L4 PRESSURE TEST OVERDUE, ,
0003136935	DA130	DP ABE EXTG 2.5KG	5W, NEW BLDG OFFICE, OPPOSITE W5.23	L4 PRESSURE TEST OVERDUE, ,

SV no: XXXX  
Printed: XX/XX/2022

Maintenance performed in accordance with AS 1851 - 2005  
Hose Reel(s) without water flow defects listed above are deemed to have PASSED - with a minimum flow of 20 l/min (for 19mm hose) or 25 l/min (for 25mm hose) in accordance with the BCA & AS1851

a division of





# FIRE EQUIPMENT SERVICES

PO Box 3070, Nunawading, Vic 3131  
www.fes.com.au e: service@fes.com.au

ABN 28 598 558 561  
Tel 1300 855 163  
Fax 1300 655 511



## ESSENTIAL SAFETY MEASURES SERVICE REPORT

The Level of Performance and Frequency of Maintenance is as required by Essential Safety Measures Requirements

Service Visit:  
Completed Date:  
Site Details: **XXX**

### SAMPLE REPORT

Work Performed By: XXX

Purchase Order:

0003136938	DA130	DP ABE EXTG 2.5KG	5W, NEW BLDG OFFICE, OPPOSITE W5.31	L4 PRESSURE TEST OVERDUE, ,
0003136993	DA460	DP ABE EXTG 9KG	5W, NEW BLDG OFFICE, PLANT ROOM 1	L4 PRESSURE TEST OVERDUE, ,
0000915063	CO190	CO2 EXTG 3.5KG	4W, NEW BLDG, EAST ENTRY	L4 PRESSURE TEST OVERDUE, ,
0003136981	DA460	DP ABE EXTG 9KG	4W, NEW BLDG, PLANT ROOM 3	L4 PRESSURE TEST OVERDUE, ,
0000915059	CO190	CO2 EXTG 3.5KG	4W, NEW BLDG, WALL (RECESSED)	L4 PRESSURE TEST OVERDUE, ,
0003136934	DA130	DP ABE EXTG 2.5KG	4W, NEW BLDG, WALL (RECESSED)	L4 PRESSURE TEST OVERDUE, ,
0003136929	DA250	DP ABE EXTG 4.5KG	4W, NEW BLDG, DARK RM W4.56	L4 PRESSURE TEST OVERDUE, ,
0000915056	CO190	CO2 EXTG 3.5KG	4W, NEW BLDG, DARK RM W4.56	L4 PRESSURE TEST OVERDUE, ,
0000915055	CO190	CO2 EXTG 3.5KG	4W, NEW BLDG, WALL (RECESSED)	L4 PRESSURE TEST OVERDUE, ,
0003136928	DA250	DP ABE EXTG 4.5KG	4W, NEW BLDG, WEST EXIT	L4 PRESSURE TEST OVERDUE, ,
0003136979	DA460	DP ABE EXTG 9KG	4W, NEW BLDG, PLANT ROOM 2	L4 PRESSURE TEST OVERDUE, ,
0000915051	CO190	CO2 EXTG 3.5KG	4W, NEW BLDG, MIDDLE LAB	L4 PRESSURE TEST OVERDUE, ,
0000915050	CO190	CO2 EXTG 3.5KG	4W, NEW BLDG, MIDDLE LAB	L4 PRESSURE TEST OVERDUE, ,
0003136933	DA130	DP ABE EXTG 2.5KG	4W, NEW BLDG OFFICE, EAST ENTRY	L4 PRESSURE TEST OVERDUE, ,
0003136927	DA250	DP ABE EXTG 4.5KG	4W, NEW BLDG OFFICE, OPPOSITE W4.11	L4 PRESSURE TEST OVERDUE, ,
0003136930	DA130	DP ABE EXTG 2.5KG	4W, NEW BLDG OFFICE, OPPOSITE W4.23	L4 PRESSURE TEST OVERDUE, ,
0003136931	DA130	DP ABE EXTG 2.5KG	4W, NEW BLDG OFFICE, OPPOSITE W4.31	L4 PRESSURE TEST OVERDUE, ,
0003136983	DA460	DP ABE EXTG 9KG	4W, NEW BLDG OFFICE, PLANT RM WP4.40	L4 PRESSURE TEST OVERDUE, ,
0000915040	CO190	CO2 EXTG 3.5KG	3W, NEW BLDG, EAST ENTRY	L4 PRESSURE TEST OVERDUE, ,
0003136995	DA460	DP ABE EXTG 9KG	3W, NEW BLDG, PLANT ROOM 3	L4 PRESSURE TEST OVERDUE, ,
0000915038	CO190	CO2 EXTG 3.5KG	3W, NEW BLDG, WALL (RECESSED)	L4 PRESSURE TEST OVERDUE, ,
0003136926	DA250	DP ABE EXTG 4.5KG	3W, NEW BLDG, WALL (RECESSED)	L4 PRESSURE TEST OVERDUE, ,
0003136923	DA250	DP ABE EXTG 4.5KG	3W, NEW BLDG, MSCOPE RM W3.55	L4 PRESSURE TEST OVERDUE, ,
0000915035	CO190	CO2 EXTG 3.5KG	3W, NEW BLDG, MSCOPE RM W3.55	L4 PRESSURE TEST OVERDUE, ,
0003136980	DA460	DP ABE EXTG 9KG	3W, NEW BLDG, PLANT ROOM 2	L4 PRESSURE TEST OVERDUE, ,
0003136924	DA250	DP ABE EXTG 4.5KG	3W, NEW BLDG, WEST EXIT	L4 PRESSURE TEST OVERDUE, ,
0000915031	CO190	CO2 EXTG 3.5KG	3W, NEW BLDG, MIDDLE LAB	L4 PRESSURE TEST OVERDUE, ,

SV no: XXXX  
Printed: XX/XX/2022

Maintenance performed in accordance with AS 1851 - 2005  
Hose Reel(s) without water flow defects listed above are deemed to have PASSED - with a minimum flow of 20 l/min (for 19mm hose) or 25 l/min (for 25mm hose) in accordance with the BCA & AS1851

a division of





# FIRE EQUIPMENT SERVICES

PO Box 3070, Nunawading, Vic 3131  
www.fes.com.au e: service@fes.com.au

ABN 28 598 558 561  
Tel 1300 855 163  
Fax 1300 655 511



## ESSENTIAL SAFETY MEASURES SERVICE REPORT

The Level of Performance and Frequency of Maintenance is as required by Essential Safety Measures Requirements

Service Visit:  
Completed Date:  
Site Details: **XXXX**

### SAMPLE REPORT

Work Performed By: XXX

Purchase Order: **PO# XXXX**

0000915030	CO190	CO2 EXTG 3.5KG	3W, NEW BLDG, MIDDLE LAB	L4 PRESSURE TEST OVERDUE, ,
0003136921	DA130	DP ABE EXTG 2.5KG	3W, NEW BLDG OFFICE, EAST ENTRY	L4 PRESSURE TEST OVERDUE, ,
0003136922	DA250	DP ABE EXTG 4.5KG	3W, NEW BLDG OFFICE, OPPOSITE W3.11	L4 PRESSURE TEST OVERDUE, ,
0003136919	DA130	DP ABE EXTG 2.5KG	3W, NEW BLDG OFFICE, OPPOSITE W3.23	L4 PRESSURE TEST OVERDUE, ,
0003136918	DA130	DP ABE EXTG 2.5KG	3W, NEW BLDG OFFICE, OPPOSITE W3.31	L4 PRESSURE TEST OVERDUE, ,
0003136982	DA460	DP ABE EXTG 9KG	3W, NEW BLDG OFFICE, PLANT RM WP3.40	L4 PRESSURE TEST OVERDUE, ,
0003136913	DA250	DP ABE EXTG 4.5KG	2W, NEW BLDG MOUSE, WALL (RECESSED)	L4 PRESSURE TEST OVERDUE, ,
0003136912	DA250	DP ABE EXTG 4.5KG	2W, NEW BLDG MOUSE, WALL (RECESSED)	L4 PRESSURE TEST OVERDUE, ,
0000915018	CO190	CO2 EXTG 3.5KG	2W, NEW BLDG MOUSE, BESIDE W2.58	L4 PRESSURE TEST OVERDUE, ,
0003136911	DA250	DP ABE EXTG 4.5KG	2W, NEW BLDG MOUSE, O/SIDE W2.60	L4 PRESSURE TEST OVERDUE, ,
0000915015	CO190	CO2 EXTG 3.5KG	2W, NEW BLDG, O/SIDE W2.61	L4 PRESSURE TEST IS OVERDUE, ,
0003136915	DA250	DP ABE EXTG 4.5KG	2W, NEW BLDG, CLEAN WASH ROOM	L4 PRESSURE TEST OVERDUE, ,
0003136914	DA250	DP ABE EXTG 4.5KG	2W, NEW BLDG, CLEAN WASH ROOM	L4 PRESSURE TEST OVERDUE, ,
0003136916	DA250	DP ABE EXTG 4.5KG	2W, NEW BLDG, CLEAN WASH ROOM	L4 PRESSURE TEST OVERDUE, ,
0000915011	CO190	CO2 EXTG 3.5KG	2W, NEW BLDG, OFFICE W2.04	L4 PRESSURE TEST OVERDUE   NO ACCESS, ROOM BLOCKED OFF, ,
0000915010	CO190	CO2 EXTG 3.5KG	2W, NEW BLDG, OUTSIDE W2.58	L4 PRESSURE TEST DUE, ,
0003136917	DA130	DP ABE EXTG 2.5KG	2W, NEW BLDG, OUTSIDE W2.61	L4 PRESSURE TEST OVERDUE, ,
0000915008	CO190	CO2 EXTG 3.5KG	2W, NEW BLDG, W2.14 - W2.16	L4 PRESSURE TEST IS OVERDUE, ,
0000915007	CO190	CO2 EXTG 3.5KG	2W, NEW BLDG, W2.12 - W2.10	L4 PRESSURE TEST IS OVERDUE, ,
0000915006	CO190	CO2 EXTG 3.5KG	2W, NEW BLDG, W2.08 - W2.07	L4 PRESSURE TEST IS OVERDUE, ,
0000915005	CO190	CO2 EXTG 3.5KG	2W, NEW BLDG, W2.18 - W2.17	L4 PRESSURE TEST OVERDUE, ,
0003136990	DA460	DP ABE EXTG 9KG	2W XXXX, WP2.66, PLANT RM 2	L4 PRESSURE TEST OVERDUE, ,
0003136998	DA460	DP ABE EXTG 9KG	2W XXXX, WP2.23, PLANT RM 2	L4 PRESSURE TEST OVERDUE, ,
0003136975	DA250	DP ABE EXTG 4.5KG	1W, XXXX STORE, W1.92	L4 PRESSURE TEST OVERDUE, ,
0003136984	DA460	DP ABE EXTG 9KG	1W, PALLET STORE, W1.65	L4 PRESSURE TEST OVERDUE, ,
0003136985	DA460	DP ABE EXTG 9KG	1W, O/S INVENTORY, W1.16	L4 PRESSURE TEST OVERDUE, ,
0003136989	DA460	DP ABE EXTG 9KG	1W, DANGEROUS GOODS, W1.58	L4 PRESSURE TEST OVERDUE, ,
0000925395	CO190	CO2 EXTG 3.5KG	1W, DANGEROUS GOODS, W1.58	L4 PRESSURE TEST OVERDUE, ,

SV no: XXXX  
Printed: XX/XX/2022

Maintenance performed in accordance with AS 1851 - 2005  
Hose Reel(s) without water flow defects listed above are deemed to have PASSED - with a minimum flow of 20 l/min (for 19mm hose) or 25 l/min (for 25mm hose) in accordance with the BCA & AS1851

a division of





# FIRE EQUIPMENT SERVICES

PO Box 3070, Nunawading, Vic 3131  
www.fes.com.au e: service@fes.com.au

ABN 28 598 558 561  
Tel 1300 855 163  
Fax 1300 655 511



## ESSENTIAL SAFETY MEASURES SERVICE REPORT

The Level of Performance and Frequency of Maintenance is as required by Essential Safety Measures Requirements

Service Visit:  
Completed Date:  
Site Details: **XXXX**

### SAMPLE REPORT

Work Performed By: XXX

Purchase Order: **PO# XXXX**

0003136973	DA250	DP ABE EXTG 4.5KG	1W, O/SIDE, MEDIA P W1.53	L4 PRESSURE TEST OVERDUE, ,
0003136971	DA250	DP ABE EXTG 4.5KG	1W, LIFT FOYER, RAISING DOOR	L4 PRESSURE TEST OVERDUE, ,
0003136986	DA460	DP ABE EXTG 9KG	BASEMENT (W), SWITCH RM, WB.34	L4 PRESSURE TEST OVERDUE, ,
0003136972	DA250	DP ABE EXTG 4.5KG	BASEMENT, RAMP, 1W, LIFT FOYER, BASE OF STAIRS	L4 PRESSURE TEST OVERDUE, ,
0003136977	DA250	DP ABE EXTG 4.5KG	1W, TOILETS, LIFT FOYER	L4 PRESSURE TEST OVERDUE, ,
0003136978	DA250	DP ABE EXTG 4.5KG	5C, WEST EXIT, CENTRAL STAIRS	L4 PRESSURE TEST OVERDUE, ,
0003107974	CO190	CO2 EXTG 3.5KG	5C, WEST EXIT, RECESSED	L4 PRESSURE TEST OVERDUE, ,
0003136939	DA130	DP ABE EXTG 2.5KG	5C, OPP C5.75, RECESSED	L4 PRESSURE TEST OVERDUE, ,
0000925355	CO190	CO2 EXTG 3.5KG	5C, OPP C5.71	L4 PRESSURE TEST OVERDUE, ,
0000925353	CO190	CO2 EXTG 3.5KG	5C, MIDDLE LAB, RECESSED	L4 PRESSURE TEST OVERDUE, ,
0000925351	CO190	CO2 EXTG 3.5KG	5C, MIDDLE LAB, RECESSED	L4 PRESSURE TEST IS OVERDUE, ,
0003136937	DA130	DP ABE EXTG 2.5KG	5C, EAST EXIT, C5.59	L4 PRESSURE TEST OVERDUE, ,
0000925349	CO190	CO2 EXTG 3.5KG	3C, OFFICE, WEST EXIT 3C, SAFETY SHOWER, PREP LAB	L4 PRESSURE TEST IS OVERDUE, ,
0003136920	DA130	DP ABE EXTG 2.5KG	C3.65	L4 PRESSURE TEST OVERDUE, ,
0003060699	CO190	CO2 EXTG 3.5KG	3E, EAST EXIT, WET LAB	L4 PRESSURE TEST OVERDUE, ,
0000925316	CO190	CO2 EXTG 3.5KG	E3.24	L4 PRESSURE TEST OVERDUE, ,
0003060738	CO190	CO2 EXTG 3.5KG	6W, LIFT FOYER, EAST EXIT	L4 PRESSURE TEST OVERDUE, ,
0003136964	DA250	DP ABE EXTG 4.5KG	7W, NEW BLDG, AT WEST STAIRS	L4 PRESSURE TEST OVERDUE, ,
0003060772	SW460	SPW EXTG 9L	7W, TEA ROOM	L4 PRESSURE TEST IS OVERDUE, ,
0003060767	SW460	SPW EXTG 9L	7W, TOP OF STAIRS, OPP THEATRE	L4 PRESSURE TEST IS OVERDUE, ,
0003060755	FB003	FIRE BLANKET 1.2Mx1.8M	6, AT SHOWER, OPP C6.53A	HAS BEEN REMOVED   Not Found, ,
0003060740	CO190	CO2 EXTG 3.5KG	6W, NEW BLDG, WALL (RECESSED)	L4 PRESSURE TEST OVERDUE, ,
0003060716	CO190	CO2 EXTG 3.5KG	4W, EQUIPMENT ROOM, W4.81	L4 PRESSURE TEST OVERDUE, ,
0003136925	DA250	DP ABE EXTG 4.5KG	3W, EQUIPMENT ROOM, W3.86	L4 PRESSURE TEST OVERDUE, ,
0003060712	CO190	CO2 EXTG 3.5KG	3W, TISSUE CULT 6, OPP SHOWER	L4 PRESSURE TEST OVERDUE, ,
0003136910	DA250	DP ABE EXTG 4.5KG	2W, LIFT FOYER	L4 PRESSURE TEST OVERDUE, ,
0003060694	CO190	CO2 EXTG 3.5KG	2W, LIFT FOYER	L4 PRESSURE TEST OVERDUE, ,
0003136905	DA250	DP ABE EXTG 4.5KG	1E, COMMUNICAIONS, BEHIND RECEP.	L4 PRESSURE TEST OVERDUE, ,
0003136987	DA460	DP ABE EXTG 9KG	1W, NEW BLDG, ENGINEERING	L4 PRESSURE TEST OVERDUE, ,
0003136976	DA250	DP ABE EXTG 4.5KG	1W, ENGINEERING, STORES	L4 PRESSURE TEST OVERDUE, ,
0003136974	DA250	DP ABE EXTG 4.5KG	1W, ENGINEERING, ENTRY	L4 PRESSURE TEST OVERDUE, ,
0003136988	DA460	DP ABE EXTG 9KG	1W, LOADING BAY, BOTTOM OF STAIR	L4 PRESSURE TEST OVERDUE, ,
0003136953	DA250	DP ABE EXTG 4.5KG	6C, LAB, RECESSED	L4 PRESSURE TEST OVERDUE, ,

SV no: XXXX  
Printed: XX/XX/2022

Maintenance performed in accordance with AS 1851 - 2005  
Hose Reel(s) without water flow defects listed above are deemed to have PASSED - with a minimum flow of 20 l/min (for 19mm hose) or 25 l/min (for 25mm hose) in accordance with the BCA & AS1851

a division of







# FIRE EQUIPMENT SERVICES

PO Box 3070, Nunawading, Vic 3131  
www.fes.com.au e: service@fes.com.au

ABN 28 598 558 561  
Tel 1300 855 163  
Fax 1300 655 511



## ESSENTIAL SAFETY MEASURES SERVICE REPORT

The Level of Performance and Frequency of Maintenance is as required by Essential Safety Measures Requirements

Service Visit:  
Completed Date:  
Site Details: **XXX**

### SAMPLE REPORT

Work Performed By: XXX

Purchase Order: **PO# XXXX**

0003136996	DA460	DP ABE EXTG 9KG	2W DIRTY, WP2.66, PLANT RM 2	L4 PRESSURE TEST OVERDUE, ,
0003060647	HR000	HOSE REEL	1C, BIO SERVICES, ANTEROOM	No Access - Due to Construction, ,
0003136969	DA130	DP ABE EXTG 2.5KG	7E, ONCOLOGY, ON POST	L4 PRESSURE TEST OVERDUE, ,
0003136968	DA130	DP ABE EXTG 2.5KG	7W, TEA ROOM ENTRY, RECESSED	L4 PRESSURE TEST OVERDUE, ,
0003136954	DA250	DP ABE EXTG 4.5KG	6, PLANT ROOM, E6.52B	L4 PRESSURE TEST OVERDUE, ,
0003136958	DA250	DP ABE EXTG 4.5KG	6W, NEW BLDG, EQIP ROOM W6.79	L4 PRESSURE TEST OVERDUE, ,
0003136950	DA130	DP ABE EXTG 2.5KG	6W, NEW BLDG, EQIP ROOM W6.79	L4 PRESSURE TEST OVERDUE, ,
0003136957	DA130	DP ABE EXTG 2.5KG	6, PLANT ROOM, E6.52B	L4 PRESSURE TEST OVERDUE, ,
0003136948	DA130	DP ABE EXTG 2.5KG	6, PLANT ROOM, OPP C6.71	L4 PRESSURE TEST OVERDUE, ,
0003136909	DA130	DP ABE EXTG 2.5KG	2W DIRTY, DECONTAMINATION, 1E, BEHIND LEDS, PRE ACTION ROOM	L4 PRESSURE TEST OVERDUE, ,
0003136906	DA130	DP ABE EXTG 2.5KG	1, LOADING BAY, ON FORK	L4 PRESSURE TEST OVERDUE, ,
0003136904	DA040	DP ABE EXTG 1KG	1, ENGINEERING, OVER SINK	L4 PRESSURE TEST OVERDUE, ,
0003136908	DA130	DP ABE EXTG 2.5KG	BASEMENT, PUMP ROOM	L4 PRESSURE TEST OVERDUE, ,
0003136907	DA130	DP ABE EXTG 2.5KG	7W, W7.80, YEAST ROOM	L4 PRESSURE TEST OVERDUE, ,
0003136872	CO190	CO2 EXTG 3.5KG	7W, MEDICINAL CHEM, W7.83	L4 PRESSURE TEST IS OVERDUE, ,
0003136612	CO190	CO2 EXTG 3.5KG	7W, TEA ROOM, OPP MICROWAVES	L4 PRESSURE TEST IS OVERDUE, ,
0003136613	DA250	DP ABE EXTG 4.5KG	7W, TEA ROOM, AT MICROWAVES	L4 PRESSURE TEST IS OVERDUE, ,
0003136616	DA250	DP ABE EXTG 4.5KG	7W, TEA ROOM OFFICE 7W,	L4 PRESSURE TEST IS OVERDUE, ,
0003136619	DA130	DP ABE EXTG 2.5KG	TEA ROOM, OPP THEATRE	L4 PRESSURE TEST IS OVERDUE, ,
0003136621	DA130	DP ABE EXTG 2.5KG	7W, THEATRE TOP, OFF TEA ROOM	L4 PRESSURE TEST IS OVERDUE, ,
0003136614	DA250	DP ABE EXTG 4.5KG	7E, ONCOLOGY, AT QUIET ROOM	L4 PRESSURE TEST IS OVERDUE, ,
0003136618	DA130	DP ABE EXTG 2.5KG	7W, LIFT FOYER, O/S MALE TOILET	L4 PRESSURE TEST IS OVERDUE, ,
0003136615	DA250	DP ABE EXTG 4.5KG	7W, THEATRE LOWER 6C, WESTERN EXIT, TISSUE CULT 1	L4 PRESSURE TEST IS OVERDUE, ,
0003136620	DA130	DP ABE EXTG 2.5KG	6C, GOODS LIFT, OPP C6.52A	L4 PRESSURE TEST IS OVERDUE, ,
0003136609	DA460	DP ABE EXTG 9KG	6C, MIDDLE LAB, IN CUPBOARD	L4 PRESSURE TEST IS OVERDUE, ,
0003136604	DA250	DP ABE EXTG 4.5KG	6C, O/S CLEANERS ST, C6.60	L4 PRESSURE TEST IS OVERDUE, ,
0003136606	DA250	DP ABE EXTG 4.5KG	6C, IN CUPBOARD, LAB MIDDLE	L4 PRESSURE TEST IS OVERDUE, ,
0003136607	DA250	DP ABE EXTG 4.5KG	6C, EQUIPMENT ROOM, C6.82	L4 PRESSURE TEST IS OVERDUE, ,
0003136608	DA250	DP ABE EXTG 4.5KG		L4 PRESSURE TEST IS OVERDUE, ,
0003136605	DA250	DP ABE EXTG 4.5KG		L4 PRESSURE TEST IS OVERDUE, ,

SV no: XXXX  
Printed: XX/XX/2022

Maintenance performed in accordance with AS 1851 - 2005  
Hose Reel(s) without water flow defects listed above are deemed to have PASSED - with a minimum flow of 20 l/min (for 19mm hose) or 25 l/min (for 25mm hose) in accordance with the BCA & AS1851

a division of





# FIRE EQUIPMENT SERVICES

PO Box 3070, Nunawading, Vic 3131  
www.fes.com.au e: service@fes.com.au

ABN 28 598 558 561  
Tel 1300 855 163  
Fax 1300 655 511



## ESSENTIAL SAFETY MEASURES SERVICE REPORT

The Level of Performance and Frequency of Maintenance is as required by Essential Safety Measures Requirements

Service Visit:  
Completed Date:  
Site Details: **XXXX**

### SAMPLE REPORT

Work Performed By: XXX

Purchase Order: **PO# XXXX**

0003136611	DA460	DP ABE EXTG 9KG	6C, LIFT FOYER, O/S PLANT RM	L4 PRESSURE TEST IS OVERDUE, ,
0003136537	DA130	DP ABE EXTG 2.5KG	6C, PUMP ROOM, NEAR LIFT FOYER	L4 PRESSURE TEST IS OVERDUE, ,
0003136617	DA250	DP ABE EXTG 4.5KG	6E, LIFT FOYER	L4 PRESSURE TEST IS OVERDUE, ,
0003136540	DA130	DP ABE EXTG 2.5KG	6E, OFFICE AREA, E6.52A	L4 PRESSURE TEST IS OVERDUE, ,
0003136541	DA130	DP ABE EXTG 2.5KG	6E, OFFICE AREA, ON POLE	L4 PRESSURE TEST IS OVERDUE, ,
0003136610	DA460	DP ABE EXTG 9KG	6E, O/S EAST PLANT, E6.52B	L4 PRESSURE TEST IS OVERDUE, ,
0003136536	DA130	DP ABE EXTG 2.5KG	6E, OFFICE AREA, ON POLE	L4 PRESSURE TEST IS OVERDUE, ,
0003136539	DA130	DP ABE EXTG 2.5KG	6C, OFFICE RECESSED	L4 PRESSURE TEST IS OVERDUE, ,
0003136534	DA130	DP ABE EXTG 2.5KG	6C, OFFICE AT GREEN	L4 PRESSURE TEST IS OVERDUE, ,
0003136622	DA130	DP ABE EXTG 2.5KG	6C, OFFICE RECESSED	L4 PRESSURE TEST IS OVERDUE, ,
0003136532	DA250	DP ABE EXTG 4.5KG	5E, LIFT FOYER	L4 PRESSURE TEST IS OVERDUE, ,
0003136522	DA130	DP ABE EXTG 2.5KG	5C, EAST OFFICE EXT	L4 PRESSURE TEST IS OVERDUE, ,
0003136530	DA130	DP ABE EXTG 2.5KG	5C, OFFICE TO LAB	L4 PRESSURE TEST IS OVERDUE, ,
0003136526	DA130	DP ABE EXTG 2.5KG	5C, OFFICE, OPP C5.08	L4 PRESSURE TEST IS OVERDUE, ,
0003136529	DA130	DP ABE EXTG 2.5KG	5E, OFFICE RECESSED, AT LAB ENTRY	L4 PRESSURE TEST IS OVERDUE, ,
0003136531	DA130	DP ABE EXTG 2.5KG	5E, LAB RECESSED	L4 PRESSURE TEST IS OVERDUE, ,
0003136527	DA130	DP ABE EXTG 2.5KG	5E, O/S EAST PLANT, E5.77A	L4 PRESSURE TEST IS OVERDUE, ,
0003136528	DA130	DP ABE EXTG 2.5KG	5E, LAB RECESSED, E5.71	L4 PRESSURE TEST IS OVERDUE, ,
0003136533	DA250	DP ABE EXTG 4.5KG	2C, COO OFFICE, C2.07	L4 PRESSURE TEST IS OVERDUE, ,
0003136518	DA130	DP ABE EXTG 2.5KG	7E, PLANT RM, BEHIND ONCOLOGY	L4 PRESSURE TEST IS OVERDUE, ,
0003136506	DA250	DP ABE EXTG 4.5KG	3W, EAST EXIT, GLASS DOORS	L4 PRESSURE TEST IS OVERDUE, ,
0003136516	DA460	DP ABE EXTG 9KG	3C, CENTRAL PLANT, C3.80A	L4 PRESSURE TEST IS OVERDUE, ,
0003136507	DA250	DP ABE EXTG 4.5KG	3C, TISSUE CULTURE, C3.74	L4 PRESSURE TEST IS OVERDUE, ,
0003136509	DA250	DP ABE EXTG 4.5KG	3C, LAB WALL, OPP WALL C3.73	L4 PRESSURE TEST IS OVERDUE, ,
0003136512	DA250	DP ABE EXTG 4.5KG	3C, GOODS LIFT, C3.55A	L4 PRESSURE TEST IS OVERDUE, ,
0003136508	DA250	DP ABE EXTG 4.5KG	3C, EQUIPMENT ROOM, C3.54	L4 PRESSURE TEST IS OVERDUE, ,
0003136513	DA250	DP ABE EXTG 4.5KG	3C, ANALYSERS, C3.67	L4 PRESSURE TEST IS OVERDUE, ,
0003136511	DA250	DP ABE EXTG 4.5KG	3C, LIFT FOYER	L4 PRESSURE TEST IS OVERDUE, ,
0003136510	DA250	DP ABE EXTG 4.5KG	3E, OFFICE AREA, STORAGE E3.07	L4 PRESSURE TEST IS OVERDUE, ,
0003136514	DA250	DP ABE EXTG 4.5KG	3E, WORKSTATIONS, E3.34	L4 PRESSURE TEST IS OVERDUE, ,
0003136515	DA250	DP ABE EXTG 4.5KG	3E, LAB E3.21, MICROSCOPE RM	L4 PRESSURE TEST IS OVERDUE, ,
0003136519	DA130	DP ABE EXTG 2.5KG	3C, OFFICE ON POLE, EAST EXIT	L4 PRESSURE TEST IS OVERDUE, ,
0003136520	DA130	DP ABE EXTG 2.5KG	3C, OFFICE. BESIDE, LAB ENTRY	L4 PRESSURE TEST IS OVERDUE, ,
0003136499	DA250	DP ABE EXTG 4.5KG	2E, H/R E2.16, EAST EXIT DOOR	L4 PRESSURE TEST IS OVERDUE, ,
0003136500	DA250	DP ABE EXTG 4.5KG	4W, EQUIPMENT ROOM, W4.81	L4 PRESSURE TEST IS OVERDUE, ,
0003136494	DA250	DP ABE EXTG 4.5KG	4C, CORRIDOR, INSECTORY	L4 PRESSURE TEST IS OVERDUE, ,

SV no: XXXX  
Printed: XX/XX/2022

Maintenance performed in accordance with AS 1851 - 2005  
Hose Reel(s) without water flow defects listed above are deemed to have PASSED - with a minimum flow of 20 l/min (for 19mm hose) or 25 l/min (for 25mm hose) in accordance with the BCA & AS1851

a division of





# FIRE EQUIPMENT SERVICES

PO Box 3070, Nunawading, Vic 3131  
www.fes.com.au e: service@fes.com.au

ABN 28 598 558 561  
Tel 1300 855 163  
Fax 1300 655 511



## ESSENTIAL SAFETY MEASURES SERVICE REPORT

The Level of Performance and Frequency of Maintenance is as required by Essential Safety Measures Requirements

Service Visit:  
Completed Date:  
Site Details: **XXXX**

### SAMPLE REPORT

Work Performed By: XXX

Purchase Order: **PO# XXXX**

0003136505	DA460	DP ABE EXTG 9KG	4C, WEST PLANT ROOM, WEST EXIT	L4 PRESSURE TEST IS OVERDUE, ,
0003136501	DA250	DP ABE EXTG 4.5KG	4C, HALLWAY, O/S C4.09	L4 PRESSURE TEST IS OVERDUE, ,
0003136503	DA250	DP ABE EXTG 4.5KG	4C, LIFT FOYER	L4 PRESSURE TEST IS OVERDUE, ,
0003136495	DA250	DP ABE EXTG 4.5KG	4E, LAB E4.71, FREEZER ROOM	L4 PRESSURE TEST IS OVERDUE, ,
0003136504	DA460	DP ABE EXTG 9KG	4E, EASTERN LAB, PLANT E4.77A	L4 PRESSURE TEST IS OVERDUE, ,
0003136496	DA250	DP ABE EXTG 4.5KG	4E, LAB RECESSED	L4 PRESSURE TEST IS OVERDUE, ,
0003136497	DA250	DP ABE EXTG 4.5KG	4C, CLEAN MOUSE, O/S C4.41	L4 PRESSURE TEST IS OVERDUE, ,
0003136498	DA250	DP ABE EXTG 4.5KG	1W, ENGINEERING, SPARE	L4 PRESSURE TEST IS OVERDUE, ,
0003136493	DA250	DP ABE EXTG 4.5KG	1C, GOODS LIFT, GAS STORE C1.62	L4 PRESSURE TEST IS OVERDUE, ,
0003136488	DA250	DP ABE EXTG 4.5KG	1C, NEAR CRYO, & DRY ICE	L4 PRESSURE TEST IS OVERDUE, ,
0003136492	DA250	DP ABE EXTG 4.5KG	1C, AT CRYO ENTRY, & DRY ICE	L4 PRESSURE TEST IS OVERDUE AND GUAGE IS BROKEN, ,
0003136491	DA250	DP ABE EXTG 4.5KG	1C, GLASS DOORS, RECESSED	L4 PRESSURE TEST IS OVERDUE, ,
0003136487	DA250	DP ABE EXTG 4.5KG	1W, H/R CUPBOARD, O/S CLEANING	L4 PRESSURE TEST IS OVERDUE, ,
0003136486	DA250	DP ABE EXTG 4.5KG	1W, PURCHASING, CORRIDOR	L4 PRESSURE TEST IS OVERDUE, ,
0003136490	DA250	DP ABE EXTG 4.5KG	1W, ENGINEERING, WORKSHOP W1.74	L4 PRESSURE TEST IS OVERDUE, ,
0003136489	DA250	DP ABE EXTG 4.5KG	1C, BIO SERVICES, RM C1.52	L4 PRESSURE TEST IS OVERDUE   No Access - Due to Construction, ,
0003136485	DA250	DP ABE EXTG 4.5KG	1C, BIO SERVICES, ANTEROOM	L4 PRESSURE TEST IS OVERDUE   No Access - Due to Construction, ,
0003136484	FB002	FIRE BLANKET 1.2Mx1.2M	1C, BIO SERVICES, ANTEROOM	No Access - Due to Construction, ,
0003182394	DA250	DP ABE EXTG 4.5KG	7W, OFFICE HALLWAY, ENTRY	L4 PRESSURE TEST IS OVERDUE, ,
0003182392	DA130	DP ABE EXTG 2.5KG	4E, OFFICE RECESSED	L4 PRESSURE TEST IS OVERDUE, ,
0003182391	DA130	DP ABE EXTG 2.5KG	3C, LIFT FOYER, H/R CUPBOARD	L4 PRESSURE TEST IS OVERDUE, ,
0003182393	DA250	DP ABE EXTG 4.5KG	1W, ENGINEERING, SPARE	L4 PRESSURE TEST IS OVERDUE, ,
0003182390	DA130	DP ABE EXTG 2.5KG	2C, LIFT FOYER, AT ROUND WINDOW	L4 PRESSURE TEST IS OVERDUE, ,
0003210476	DA130	DP ABE EXTG 2.5KG	4E, PLANT ROOM, E4.77A 4C,	L4 PRESSURE TEST IS OVERDUE, ,
0003210477	DA130	DP ABE EXTG 2.5KG	LINK PLANT ROOM, EL4.01D	L4 PRESSURE TEST IS OVERDUE, ,
0003210473	DA250	DP ABE EXTG 4.5KG	4C, GOODS LFT FOYER, AIRLOCK, C4.61	L4 PRESSURE TEST IS OVERDUE, ,
0003210465	DA250	DP ABE EXTG 4.5KG	1E, COMMUNICAIONS, BEHIND RECEP.	L4 PRESSURE TEST IS OVERDUE, ,
0003210468	DA250	DP ABE EXTG 4.5KG	GR, SWITCH ROOM, MOBILE STATION	L4 PRESSURE TEST IS OVERDUE, ,
0003210466	DA460	DP ABE EXTG 9KG	GR, CENTRAL, PLANT ROOM	L4 PRESSURE TEST IS OVERDUE, ,
0003210464	DA130	DP ABE EXTG 2.5KG	3C, LIFT FOYER, PLANT ROOM	L4 PRESSURE TEST IS OVERDUE, , MUST BE MINIMUM 2 METRES AWAY FROM SWITCHBOARD, L4 PRESSURE TEST IS OVERDUE, ,

SV no: XXXX  
Printed: XX/XX/2022

Maintenance performed in accordance with AS 1851 - 2005  
Hose Reel(s) without water flow defects listed above are deemed to have PASSED - with a minimum flow of  
20 l/min (for 19mm hose) or 25 l/min (for 25mm hose) in accordance with the BCA & AS1851

a division of







# FIRE EQUIPMENT SERVICES

PO Box 3070, Nunawading, Vic 3131  
www.fes.com.au e: service@fes.com.au

ABN 28 598 558 561  
Tel 1300 855 163  
Fax 1300 655 511



## ESSENTIAL SAFETY MEASURES SERVICE REPORT

The Level of Performance and Frequency of Maintenance is as required by Essential Safety Measures Requirements

Service Visit:  
Completed Date:  
Site Details: **XXXX**

### SAMPLE REPORT

Work Performed By: XXX

Purchase Order: **PO# XXXX**

0003250526	SF800	SOLBERG FM EXTG 9L	BASEMENT (W), MECHANICAL P/R, WB.29	LEVEL 3 RECHARGE OF SP FOAM EXTINGUISHER REQUIRED, ,
0003210474	DA460	DP ABE EXTG 9KG	8W, HHW PLANT ROOM, WP8.11 ENTRY	L4 PRESSURE TEST IS OVERDUE, ,
0003136521	DA250	DP ABE EXTG 4.5KG	5C, LIFT FOYER, AT ROUND WINDOW	L4 PRESSURE TEST OVERDUE, ,
0003136502	DA250	DP ABE EXTG 4.5KG	5E, FREEZER ROOM, E5.71	L4 PRESSURE TEST OVERDUE, ,
0003396182	DA130	DP ABE EXTG 2.5KG	7W, THEATRE, BOOTH	L4 PRESSURE TEST OVERDUE. NEEDS MOUNTING.,
0003396183	ST460	SPF/ATC EXTG 9L	1C, OPP CRYOGENICS, C1.68 CORRIDOR	REFILL REQUIRED, ,
0003396184	ST460	SPF/ATC EXTG 9L	1W, DANGEROUS GOODS, W1.58	REFILL REQUIRED, ,
0003210472	DA130	DP ABE EXTG 2.5KG	1W, ENGINEERING, SPARE	L4 PRESSURE TEST IS OVERDUE   Not Found, ,

## COMPLETED SUMMARY

### Summary Of Work Performed

### Quantity

CO0L1	LVL1 6-MTHLY SERVICE CO2 EXTINGUISHER	67
DA0L1	LVL1 6-MTHLY SERVICE DRY POWDER ABE EXTINGUISHER	201
DA0L2	LVL2 YEARLY SERVICE DRY POWDER ABE EXTINGUISHER	3
FB0L2	SERVICE FIRE BLANKET	46
HR0L1	LVL 1 6-MTHLY SERVICE HOSE REEL	5
HR0L2	LVL 2 ANNUAL SERVICE HOSE REEL	52
SO0L1	LVL1 6-MTHLY SERVICE SPF/SOLBERG ATC EXTINGUISHER	1
ST0L1	LVL1 6-MTHLY SERVICE SPF/ATC EXTINGUISHER	2
SW0L1	LVL1 6-MTHLY SERVICE SPW EXTINGUISHER	4

## COMPLETED WORK

Equipment Serviced	Location	Service Performed
0003025612 CO2 EXTG 2KG	GR, CENTRAL, PLANT ROOM	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0003025604 CO2 EXTG 2KG	GR, SWITCHROOM	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0000925395 CO2 EXTG 3.5KG	1W, DANGEROUS GOODS, W1.58	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0003250525 CO2 EXTG 3.5KG	1W, INSTRUMENT LAB, W1.53	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0000574449 CO2 EXTG 3.5KG	2C, I.T. W/SHOP, COMPUTER RM	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0000888232 CO2 EXTG 3.5KG	2C, IT, ENTRY	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0003060693 CO2 EXTG 3.5KG	2C, IT OFFICE, END OF CORRIDOR	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0003060694 CO2 EXTG 3.5KG	2W, LIFT FOYER	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0000915015 CO2 EXTG 3.5KG	2W, NEW BLDG, O/SIDE W2.61	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0000915010 CO2 EXTG 3.5KG	2W, NEW BLDG, OUTSIDE W2.58	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0000915006 CO2 EXTG 3.5KG	2W, NEW BLDG, W2.08 - W2.07	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0000915007 CO2 EXTG 3.5KG	2W, NEW BLDG, W2.12 - W2.10	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0000915008 CO2 EXTG 3.5KG	2W, NEW BLDG, W2.14 - W2.16	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0000915005 CO2 EXTG 3.5KG	2W, NEW BLDG, W2.18 - W2.17	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0000915018 CO2 EXTG 3.5KG	2W, NEW BLDG MOUSE, BESIDE W2.58	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0003060699 CO2 EXTG 3.5KG	3C, SAFETY SHOWER, PREP LAB C3.65	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG

SV no: XXXX  
Printed: XX/XX/2022

Maintenance performed in accordance with AS 1851 - 2005  
Hose Reel(s) without water flow defects listed above are deemed to have PASSED - with a minimum flow of  
20 l/min (for 19mm hose) or 25 l/min (for 25mm hose) in accordance with the BCA & AS1851

a division of





# FIRE EQUIPMENT SERVICES

PO Box 3070, Nunawading, Vic 3131  
www.fes.com.au e: service@fes.com.au

ABN 28 598 558 561  
Tel 1300 855 163  
Fax 1300 655 511



## ESSENTIAL SAFETY MEASURES SERVICE REPORT

The Level of Performance and Frequency of Maintenance is as required by Essential Safety Measures Requirements

Service Visit:  
Completed Date:  
Site Details: XXXX

### SAMPLE REPORT

Work Performed By: XXX

Purchase Order: PO# XXXX

## COMPLETED WORK

Equipment Serviced	Location	Service Performed
0000925316 CO2 EXTG 3.5KG	3E, EAST EXIT, WET LAB E3.24	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0000915040 CO2 EXTG 3.5KG	3W, NEW BLDG, EAST ENTRY	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0000915030 CO2 EXTG 3.5KG	3W, NEW BLDG, MIDDLE LAB	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0000915031 CO2 EXTG 3.5KG	3W, NEW BLDG, MIDDLE LAB	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0000915035 CO2 EXTG 3.5KG	3W, NEW BLDG, MSCOPE RM W3.55	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0000915038 CO2 EXTG 3.5KG	3W, NEW BLDG, WALL (RECESSED)	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0003060712 CO2 EXTG 3.5KG	3W, TISSUE CULT 6, OPP SHOWER	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0003250520 CO2 EXTG 3.5KG	4C, OPP CELL PREP, C4.33 EYEWASH	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0003060716 CO2 EXTG 3.5KG	4W, EQUIPMENT ROOM, W4.81	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0000915056 CO2 EXTG 3.5KG	4W, NEW BLDG, DARK RM W4.56	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0000915063 CO2 EXTG 3.5KG	4W, NEW BLDG, EAST ENTRY	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0000915050 CO2 EXTG 3.5KG	4W, NEW BLDG, MIDDLE LAB	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0000915051 CO2 EXTG 3.5KG	4W, NEW BLDG, MIDDLE LAB	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0000915055 CO2 EXTG 3.5KG	4W, NEW BLDG, WALL (RECESSED)	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0000915059 CO2 EXTG 3.5KG	4W, NEW BLDG, WALL (RECESSED)	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0000925349 CO2 EXTG 3.5KG	5C, EAST EXIT, C5.59	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0000925351 CO2 EXTG 3.5KG	5C, MIDDLE LAB, RECESSED	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0000925353 CO2 EXTG 3.5KG	5C, OPP C5.71	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0000925355 CO2 EXTG 3.5KG	5C, OPP C5.75, RECESSED	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0003107974 CO2 EXTG 3.5KG	5C, WEST EXIT, CENTRAL STAIRS	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0003330432 CO2 EXTG 3.5KG	5E, NEW LAB, NEAR LIFT	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0000915085 CO2 EXTG 3.5KG	5W, NEW BLDG, EAST ENTRY	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0000915078 CO2 EXTG 3.5KG	5W, NEW BLDG, GEL RM W5.55	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0000915072 CO2 EXTG 3.5KG	5W, NEW BLDG, MIDDLE LAB	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0000915073 CO2 EXTG 3.5KG	5W, NEW BLDG, MIDDLE LAB	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0000915071 CO2 EXTG 3.5KG	5W, NEW BLDG, N/E LAB CORNER	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0000915077 CO2 EXTG 3.5KG	5W, NEW BLDG, WALL (RECESSED)	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0003060734 CO2 EXTG 3.5KG	5W, NEW BLDG, WALL (RECESSED)	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0003060738 CO2 EXTG 3.5KG	6W, LIFT FOYER, EAST EXIT	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0000915098 CO2 EXTG 3.5KG	6W, NEW BLDG, COLDROOM 2A	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0000915104 CO2 EXTG 3.5KG	6W, NEW BLDG, EAST ENTRY	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0000915100 CO2 EXTG 3.5KG	6W, NEW BLDG, EQUIP RM W6.79	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0000915093 CO2 EXTG 3.5KG	6W, NEW BLDG, WALL (RECESSED)	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0000915102 CO2 EXTG 3.5KG	6W, NEW BLDG, WALL (RECESSED)	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0003060740 CO2 EXTG 3.5KG	6W, NEW BLDG, WALL (RECESSED)	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0003060742 CO2 EXTG 3.5KG	6W, NEW BLDG, WALL (RECESSED)	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0003136612 CO2 EXTG 3.5KG	7W, MEDICINAL CHEM, W7.83	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0003210543 CO2 EXTG 3.5KG	7W, NEW BLDG, EAST EXIT	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0003060785 CO2 EXTG 3.5KG	7W, NEW BLDG, MED CHEM W7.83	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0000915116 CO2 EXTG 3.5KG	7W, NEW BLDG, WALL (RECESSED)	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0000915117 CO2 EXTG 3.5KG	7W, NEW BLDG, WALL (RECESSED)	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0000915118 CO2 EXTG 3.5KG	7W, NEW BLDG, WALL (RECESSED)	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0000915121 CO2 EXTG 3.5KG	7W, NEW BLDG, WEST EXIT	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0000915112 CO2 EXTG 3.5KG	7W, NEW BLDG OFFICE, DIRECTORATE KIT	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG

SV no: XXXX  
Printed: XX/XX/2022

Maintenance performed in accordance with AS 1851 - 2005  
Hose Reel(s) without water flow defects listed above are deemed to have PASSED - with a minimum flow of 20 l/min (for 19mm hose) or 25 l/min (for 25mm hose) in accordance with the BCA & AS1851

a division of





# FIRE EQUIPMENT SERVICES

PO Box 3070, Nunawading, Vic 3131  
www.fes.com.au e: service@fes.com.au

ABN 28 598 558 561  
Tel 1300 855 163  
Fax 1300 655 511



## ESSENTIAL SAFETY MEASURES SERVICE REPORT

The Level of Performance and Frequency of Maintenance is as required by Essential Safety Measures Requirements

Service Visit:  
Completed Date:  
Site Details: **XXXX**

### SAMPLE REPORT

Work Performed By: XXX

Purchase Order: **PO# XXXX**

## COMPLETED WORK

Equipment Serviced	Location	Service Performed
0003136872 CO2 EXTG 3.5KG	7W, W7.80, YEAST ROOM	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0003330434 CO2 EXTG 5KG	5C, INSTRUMENT ROOM, BESIDE LIFT	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0000115692 CO2 EXTG 5KG	8C, LMR, (MAIN)	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0000115693 CO2 EXTG 5KG	8C, LMR, (MAIN)	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0000845320 CO2 EXTG 5KG	8C, LMR, UP STAIRS	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0003060681 CO2 EXTG 5KG	BASEMENT, PUMP, ROOM	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0003060682 CO2 EXTG 5KG	BASEMENT, PUMP, ROOM	CO0L1 L1 6-MTHLY SERVICE CO2 EXTG
0003136904 DP ABE EXTG 1KG	1, LOADING BAY, ON FORK	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136908 DP ABE EXTG 2.5KG	1, ENGINEERING, OVER SINK	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136906 DP ABE EXTG 2.5KG	1E, BEHIND LEDS, PRE ACTION ROOM	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003182390 DP ABE EXTG 2.5KG	2C, LIFT FOYER, AT ROUND WINDOW	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003025614 DP ABE EXTG 2.5KG	2C, LIFT FOYER, OUTSIDE I.T.	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003025613 DP ABE EXTG 2.5KG	2C, PLANT RM WEST, C2.70A	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003025611 DP ABE EXTG 2.5KG	2C, WEST EXIT, CENTRAL STAIRS	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136917 DP ABE EXTG 2.5KG	2W, NEW BLDG, OUTSIDE W2.61	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136909 DP ABE EXTG 2.5KG	2W DIRTY, DECONTAMINATION, DIRTY AREA	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003182391 DP ABE EXTG 2.5KG	3C, LIFT FOYER, H/R CUPBOARD	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003210464 DP ABE EXTG 2.5KG	3C, LIFT FOYER, PLANT ROOM	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136920 DP ABE EXTG 2.5KG	3C, OFFICE, WEST EXIT	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136519 DP ABE EXTG 2.5KG	3C, OFFICE ON POLE, EAST EXIT	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136520 DP ABE EXTG 2.5KG	3C, OFFICE, BESIDE, LAB ENTRY	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003396181 DP ABE EXTG 2.5KG	3E, EAST PLANT ROOM, E3.24	DA0L2 L2 YEARLY SERVICE DP ABE EXTG
0003136921 DP ABE EXTG 2.5KG	3W, NEW BLDG OFFICE, EAST ENTRY	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136919 DP ABE EXTG 2.5KG	3W, NEW BLDG OFFICE, OPPOSITE W3.23	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136918 DP ABE EXTG 2.5KG	3W, NEW BLDG OFFICE, OPPOSITE W3.31	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003210477 DP ABE EXTG 2.5KG	4C, LINK PLANT ROOM, EL4.01D	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003182392 DP ABE EXTG 2.5KG	4E, OFFICE RECESSED	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003210476 DP ABE EXTG 2.5KG	4E, PLANT ROOM, E4.77A	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003025610 DP ABE EXTG 2.5KG	4W, LIFT FOYER, RECESS	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136934 DP ABE EXTG 2.5KG	4W, NEW BLDG, WALL (RECESSED)	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136933 DP ABE EXTG 2.5KG	4W, NEW BLDG OFFICE, EAST ENTRY	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136930 DP ABE EXTG 2.5KG	4W, NEW BLDG OFFICE, OPPOSITE W4.23	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136931 DP ABE EXTG 2.5KG	4W, NEW BLDG OFFICE, OPPOSITE W4.31	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136522 DP ABE EXTG 2.5KG	5C, EAST OFFICE EXT	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136937 DP ABE EXTG 2.5KG	5C, MIDDLE LAB, RECESSED	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136526 DP ABE EXTG 2.5KG	5C, OFFICE, OPP C5.08	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136530 DP ABE EXTG 2.5KG	5C, OFFICE TO LAB	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003210475 DP ABE EXTG 2.5KG	5C, OPP C5.75, IN CUPBOARD	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003025608 DP ABE EXTG 2.5KG	5C, PLANT ROOM, C5.80B	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136939 DP ABE EXTG 2.5KG	5C, WEST EXIT, RECESSED	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136531 DP ABE EXTG 2.5KG	5E, LAB RECESSED	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136528 DP ABE EXTG 2.5KG	5E, LAB RECESSED, E5.71	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG

SV no: XXXX  
Printed: XX/XX/2022

Maintenance performed in accordance with AS 1851 - 2005  
Hose Reel(s) without water flow defects listed above are deemed to have PASSED - with a minimum flow of 20 l/min (for 19mm hose) or 25 l/min (for 25mm hose) in accordance with the BCA & AS1851

a division of





# FIRE EQUIPMENT SERVICES

PO Box 3070, Nunawading, Vic 3131  
www.fes.com.au e: service@fes.com.au

ABN 28 598 558 561  
Tel 1300 855 163  
Fax 1300 655 511



## ESSENTIAL SAFETY MEASURES SERVICE REPORT

The Level of Performance and Frequency of Maintenance is as required by Essential Safety Measures Requirements

Service Visit:  
Completed Date:  
Site Details: **XXXX**

### SAMPLE REPORT

Work Performed By: XXX

Purchase Order: **PO# XXXX**

## COMPLETED WORK

Equipment Serviced	Location	Service Performed
0003136527 DP ABE EXTG 2.5KG	5E, O/S EAST PLANT, E5.77A	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136529 DP ABE EXTG 2.5KG	5E, OFFICE RECESSED, AT LAB ENTRY	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136936 DP ABE EXTG 2.5KG	5W, NEW BLDG OFFICE, EAST ENTRY	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136935 DP ABE EXTG 2.5KG	5W, NEW BLDG OFFICE, OPPOSITE W5.23	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136938 DP ABE EXTG 2.5KG	5W, NEW BLDG OFFICE, OPPOSITE W5.31	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136957 DP ABE EXTG 2.5KG	6, PLANT ROOM, E6.52B	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136948 DP ABE EXTG 2.5KG	6, PLANT ROOM, OPP C6.71	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136534 DP ABE EXTG 2.5KG	6C, OFFICE AT GREEN	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136539 DP ABE EXTG 2.5KG	6C, OFFICE RECESSED	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136622 DP ABE EXTG 2.5KG	6C, OFFICE RECESSED	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136537 DP ABE EXTG 2.5KG	6C, PUMP ROOM, NEAR LIFT FOYER	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136540 DP ABE EXTG 2.5KG	6E, OFFICE AREA, E6.52A	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136536 DP ABE EXTG 2.5KG	6E, OFFICE AREA, ON POLE	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136541 DP ABE EXTG 2.5KG	6E, OFFICE AREA, ON POLE	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136950 DP ABE EXTG 2.5KG	6W, NEW BLDG, EQUIP ROOM W6.79	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136947 DP ABE EXTG 2.5KG	6W, NEW BLDG OFFICE, EAST LOUNGE	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136949 DP ABE EXTG 2.5KG	6W, NEW BLDG OFFICE, GREEN RECESSED	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136946 DP ABE EXTG 2.5KG	6W, NEW BLDG OFFICE, WALL (RECESSED)	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136618 DP ABE EXTG 2.5KG	7E, ONCOLOGY, AT QUIET ROOM	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136969 DP ABE EXTG 2.5KG	7E, ONCOLOGY, ON POST	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136518 DP ABE EXTG 2.5KG	7E, PLANT RM, BEHIND ONCOLOGY	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003060664 DP ABE EXTG 2.5KG	7W, LIFT FOYER, RECESSED	DA0L2 L2 YEARLY SERVICE DP ABE EXTG
0003136966 DP ABE EXTG 2.5KG	7W, NEW BLDG OFFICE, GREEN -RECESSED	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136945 DP ABE EXTG 2.5KG	7W, NEW BLDG OFFICE, GREEN-RECESSED	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136621 DP ABE EXTG 2.5KG	7W, TEA ROOM, OPP THEATRE	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136968 DP ABE EXTG 2.5KG	7W, TEA ROOM ENTRY, RECESSED	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136619 DP ABE EXTG 2.5KG	7W, TEA ROOM OFFICE	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003396182 DP ABE EXTG 2.5KG	7W, THEATRE, BOOTH	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136620 DP ABE EXTG 2.5KG	7W, THEATRE LOWER	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003025607 DP ABE EXTG 2.5KG	8C, WEST PLANT, NEAR ROOF EXIT	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136907 DP ABE EXTG 2.5KG	BASEMENT, PUMP ROOM	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003025602 DP ABE EXTG 2.5KG	BASEMENT, RADIATION	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003025603 DP ABE EXTG 2.5KG	BASEMENT, RADIATION	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003025615 DP ABE EXTG 2.5KG	GR, CENTRAL PLANT, GENERATOR ROOM	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003025616 DP ABE EXTG 2.5KG	GR, CENTRAL PLANT, GENERATOR ROOM	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136492 DP ABE EXTG 4.5KG	1C, AT CRYO ENTRY, & DRY ICE	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136491 DP ABE EXTG 4.5KG	1C, GLASS DOORS, RECESSED	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136493 DP ABE EXTG 4.5KG	1C, GOODS LIFT, GAS STORE C1.62	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG

SV no: XXXX  
Printed: XX/XX/2022

Maintenance performed in accordance with AS 1851 - 2005  
Hose Reel(s) without water flow defects listed above are deemed to have PASSED - with a minimum flow of 20 l/min (for 19mm hose) or 25 l/min (for 25mm hose) in accordance with the BCA & AS1851

a division of







# FIRE EQUIPMENT SERVICES

PO Box 3070, Nunawading, Vic 3131  
www.fes.com.au e: service@fes.com.au

ABN 28 598 558 561  
Tel 1300 855 163  
Fax 1300 655 511



## ESSENTIAL SAFETY MEASURES SERVICE REPORT

The Level of Performance and Frequency of Maintenance is as required by Essential Safety Measures Requirements

Service Visit:  
Completed Date:  
Site Details: **XXXX**

### SAMPLE REPORT

Work Performed By: XXX

Purchase Order: **PO# XXXX**

## COMPLETED WORK

Equipment Serviced	Location	Service Performed
0003136488 DP ABE EXTG 4.5KG	1C, NEAR CRYO, & DRY ICE	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136905 DP ABE EXTG 4.5KG	1E, COMMUNICAIONS, BEHIND RECEP.	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003210465 DP ABE EXTG 4.5KG	1E, COMMUNICAIONS, BEHIND RECEP.	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136975 DP ABE EXTG 4.5KG	1W, ANIMAL STORE, W1.92	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136974 DP ABE EXTG 4.5KG	1W, ENGINEERING, ENTRY	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136498 DP ABE EXTG 4.5KG	1W, ENGINEERING, SPARE	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003182393 DP ABE EXTG 4.5KG	1W, ENGINEERING, SPARE	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136976 DP ABE EXTG 4.5KG	1W, ENGINEERING, STORES	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136490 DP ABE EXTG 4.5KG	1W, ENGINEERING, WORKSHOP W1.74	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136487 DP ABE EXTG 4.5KG	1W, H/R CUPBOARD, O/S CLEANING	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136977 DP ABE EXTG 4.5KG	1W, LIFT FOYER, BASE OF STAIRS	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136971 DP ABE EXTG 4.5KG	1W, LIFT FOYER, RAISING DOOR	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136973 DP ABE EXTG 4.5KG	1W, O/SIDE, MEDIA P W1.53	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136486 DP ABE EXTG 4.5KG	1W, PURCHASING, CORRIDOR	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136978 DP ABE EXTG 4.5KG	1W, TOILETS, LIFT FOYER	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136533 DP ABE EXTG 4.5KG	2C, COO OFFICE, C2.07	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136499 DP ABE EXTG 4.5KG	2E, H/R E2.16, EAST EXIT DOOR	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136910 DP ABE EXTG 4.5KG	2W, LIFT FOYER	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136914 DP ABE EXTG 4.5KG	2W, NEW BLDG, CLEAN WASH ROOM	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136915 DP ABE EXTG 4.5KG	2W, NEW BLDG, CLEAN WASH ROOM	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136916 DP ABE EXTG 4.5KG	2W, NEW BLDG, CLEAN WASH ROOM	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136911 DP ABE EXTG 4.5KG	2W, NEW BLDG MOUSE, O/SIDE W2.60	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136912 DP ABE EXTG 4.5KG	2W, NEW BLDG MOUSE, WALL (RECESSED)	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136913 DP ABE EXTG 4.5KG	2W, NEW BLDG MOUSE, WALL (RECESSED)	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136513 DP ABE EXTG 4.5KG	3C, ANALYSERS, C3.67	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136508 DP ABE EXTG 4.5KG	3C, EQUIPMENT ROOM, C3.54	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136512 DP ABE EXTG 4.5KG	3C, GOODS LIFT, C3.55A	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136509 DP ABE EXTG 4.5KG	3C, LAB WALL, OPP WALL C3.73	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136511 DP ABE EXTG 4.5KG	3C, LIFT FOYER	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136507 DP ABE EXTG 4.5KG	3C, TISSUE CULTURE, C3.74	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136515 DP ABE EXTG 4.5KG	3E, LAB E3.21, MICROSCOPE RM	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136510 DP ABE EXTG 4.5KG	3E, OFFICE AREA, STORAGE E3.07	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136514 DP ABE EXTG 4.5KG	3E, WORKSTATIONS, E3.34	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136506 DP ABE EXTG 4.5KG	3W, EAST EXIT, GLASS DOORS	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003330439 DP ABE EXTG 4.5KG	3W, EQUIPMENT ROOM, W3.82	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136925 DP ABE EXTG 4.5KG	3W, EQUIPMENT ROOM, W3.86	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136923 DP ABE EXTG 4.5KG	3W, NEW BLDG, MSCOPE RM W3.55	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136926 DP ABE EXTG 4.5KG	3W, NEW BLDG, WALL (RECESSED)	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136924 DP ABE EXTG 4.5KG	3W, NEW BLDG, WEST EXIT	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136922 DP ABE EXTG 4.5KG	3W, NEW BLDG OFFICE, OPPOSITE W3.11	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136497 DP ABE EXTG 4.5KG	4C, CLEAN MOUSE, O/S C4.41	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG

SV no: XXXX  
Printed: XX/XX/2022

Maintenance performed in accordance with AS 1851 - 2005  
Hose Reel(s) without water flow defects listed above are deemed to have PASSED - with a minimum flow of 20 l/min (for 19mm hose) or 25 l/min (for 25mm hose) in accordance with the BCA & AS1851

a division of







# FIRE EQUIPMENT SERVICES

PO Box 3070, Nunawading, Vic 3131  
www.fes.com.au e: service@fes.com.au

ABN 28 598 558 561  
Tel 1300 855 163  
Fax 1300 655 511



## ESSENTIAL SAFETY MEASURES SERVICE REPORT

The Level of Performance and Frequency of Maintenance is as required by Essential Safety Measures Requirements

Service Visit:  
Completed Date:  
Site Details: **XXXX**

### SAMPLE REPORT

Work Performed By: XXX

Purchase Order: **PO# XXXX**

## COMPLETED WORK

Equipment Serviced	Location	Service Performed
0003136494 DP ABE EXTG 4.5KG	4C, CORRIDOR, INSECTORY	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003210473 DP ABE EXTG 4.5KG	4C, GOODS LFT FOYER, AIRLOCK, C4.61	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136501 DP ABE EXTG 4.5KG	4C, HALLWAY, O/S C4.09	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136503 DP ABE EXTG 4.5KG	4C, LIFT FOYER	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003396180 DP ABE EXTG 4.5KG	4C, WEST PLANT ROOM, CP4.15	DA0L2 L2 YEARLY SERVICE DP ABE EXTG
0003136495 DP ABE EXTG 4.5KG	4E, LAB E4.71, FREEZER ROOM	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136496 DP ABE EXTG 4.5KG	4E, LAB RECESSED	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136500 DP ABE EXTG 4.5KG	4W, EQUIPMENT ROOM, W4.81	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136929 DP ABE EXTG 4.5KG	4W, NEW BLDG, DARK RM W4.56	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136928 DP ABE EXTG 4.5KG	4W, NEW BLDG, WEST EXIT	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136927 DP ABE EXTG 4.5KG	4W, NEW BLDG OFFICE, OPPOSITE W4.11	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136521 DP ABE EXTG 4.5KG	5C, LIFT FOYER, AT ROUND WINDOW	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136502 DP ABE EXTG 4.5KG	5E, FREEZER ROOM, E5.71	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136532 DP ABE EXTG 4.5KG	5E, LIFT FOYER	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136944 DP ABE EXTG 4.5KG	5W, LIFT FOYER, GLASS DOORS	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136942 DP ABE EXTG 4.5KG	5W, NEW BLDG, GEL RM W5.55	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136943 DP ABE EXTG 4.5KG	5W, NEW BLDG, WALL (RECESSED)	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136940 DP ABE EXTG 4.5KG	5W, NEW BLDG, WEST EXIT	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136941 DP ABE EXTG 4.5KG	5W, NEW BLDG OFFICE, OPPOSITE W5.11	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136603 DP ABE EXTG 4.5KG	6, IN CUPBOARD, OPP C6.74	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136954 DP ABE EXTG 4.5KG	6, PLANT ROOM, E6.52B	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136605 DP ABE EXTG 4.5KG	6C, EQUIPMENT ROOM, C6.82	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136604 DP ABE EXTG 4.5KG	6C, GOODS LIFT, OPP C6.52A	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136608 DP ABE EXTG 4.5KG	6C, IN CUPBOARD, LAB MIDDLE	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136953 DP ABE EXTG 4.5KG	6C, LAB, RECESSED	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136606 DP ABE EXTG 4.5KG	6C, MIDDLE LAB, IN CUPBOARD	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136607 DP ABE EXTG 4.5KG	6C, O/S CLEANERS ST, C6.60	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003025601 DP ABE EXTG 4.5KG	6C, PLANT ROOM, OPPOSITE C6.71	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136617 DP ABE EXTG 4.5KG	6E, LIFT FOYER	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136952 DP ABE EXTG 4.5KG	6W, NEW BLDG, COLDROOM 2A	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136958 DP ABE EXTG 4.5KG	6W, NEW BLDG, EQIP ROOM W6.79	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136956 DP ABE EXTG 4.5KG	6W, NEW BLDG, LIFT FOYER	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136951 DP ABE EXTG 4.5KG	6W, NEW BLDG, WEST EXIT	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136955 DP ABE EXTG 4.5KG	6W, NEW BLDG OFFICE, W6.11	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003492568 DP ABE EXTG 4.5KG	7C, LIFT FOYER	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003492567 DP ABE EXTG 4.5KG	7E, ONCOLOGY, O/S E7.51	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003492565 DP ABE EXTG 4.5KG	7E, ONCOLOGY, O/S PLANT ROOM	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136960 DP ABE EXTG 4.5KG	7W, LAB AT SLIDER, WALL (RECESSED)	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136615 DP ABE EXTG 4.5KG	7W, LIFT FOYER, O/S MALE TOILET	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136964 DP ABE EXTG 4.5KG	7W, NEW BLDG, AT WEST STAIRS	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136963 DP ABE EXTG 4.5KG	7W, NEW BLDG, C.RM W7.56	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136962 DP ABE EXTG 4.5KG	7W, NEW BLDG, ECOLI W7.54	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG

SV no: XXXX  
Printed: XX/XX/2022

Maintenance performed in accordance with AS 1851 - 2005  
Hose Reel(s) without water flow defects listed above are deemed to have PASSED - with a minimum flow of 20 l/min (for 19mm hose) or 25 l/min (for 25mm hose) in accordance with the BCA & AS1851

a division of





# FIRE EQUIPMENT SERVICES

PO Box 3070, Nunawading, Vic 3131  
www.fes.com.au e: service@fes.com.au

ABN 28 598 558 561  
Tel 1300 855 163  
Fax 1300 655 511



## ESSENTIAL SAFETY MEASURES SERVICE REPORT

The Level of Performance and Frequency of Maintenance is as required by Essential Safety Measures Requirements

Service Visit:  
Completed Date:  
Site Details: **XXXX**

### SAMPLE REPORT

Work Performed By: XXX

Purchase Order: **PO# XXXX**

## COMPLETED WORK

Equipment Serviced	Location	Service Performed
0003136961 DP ABE EXTG 4.5KG	7W, NEW BLDG, WALL (RECESSED)	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136959 DP ABE EXTG 4.5KG	7W, NEW BLDG OFFICE, DIRECTORATE	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136967 DP ABE EXTG 4.5KG	7W, NEW BLDG OFFICE, EAST ENTRY	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003182394 DP ABE EXTG 4.5KG	7W, OFFICE HALLWAY, ENTRY	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136616 DP ABE EXTG 4.5KG	7W, TEA ROOM, AT MICROWAVES	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136613 DP ABE EXTG 4.5KG	7W, TEA ROOM, OPP MICROWAVES	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136614 DP ABE EXTG 4.5KG	7W, THEATRE TOP, OFF TEA ROOM	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003025606 DP ABE EXTG 4.5KG	8C, EAST PLANT, AT EXIT DOOR	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136972 DP ABE EXTG 4.5KG	BASEMENT, RAMP,	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003025617 DP ABE EXTG 9KG	1E, FIP BEHIND, RECEPTION	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136989 DP ABE EXTG 9KG	1W, DANGEROUS GOODS, W1.58	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136988 DP ABE EXTG 9KG	1W, LOADING BAY, BOTTOM OF STAIR	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136987 DP ABE EXTG 9KG	1W, NEW BLDG, ENGINEERING	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136985 DP ABE EXTG 9KG	1W, O/S INVENTORY, W1.16	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136984 DP ABE EXTG 9KG	1W, PALLET STORE, W1.65	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136998 DP ABE EXTG 9KG	2W WP2.23, PLANT RM 2	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136990 DP ABE EXTG 9KG	2W WP2.66, PLANT RM 2	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136996 DP ABE EXTG 9KG	2W WP2.66, PLANT RM 2	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136516 DP ABE EXTG 9KG	3C, CENTRAL PLANT, C3.80A	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136980 DP ABE EXTG 9KG	3W, NEW BLDG, PLANT ROOM 2	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136995 DP ABE EXTG 9KG	3W, NEW BLDG, PLANT ROOM 3	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136982 DP ABE EXTG 9KG	3W, NEW BLDG OFFICE, PLANT RM WP3.40	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136505 DP ABE EXTG 9KG	4C, WEST PLANT ROOM, WEST EXIT	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136504 DP ABE EXTG 9KG	4E, EASTERN LAB, PLANT E4.77A	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136979 DP ABE EXTG 9KG	4W, NEW BLDG, PLANT ROOM 2	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136981 DP ABE EXTG 9KG	4W, NEW BLDG, PLANT ROOM 3	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136983 DP ABE EXTG 9KG	4W, NEW BLDG OFFICE, PLANT RM WP4.40	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003330429 DP ABE EXTG 9KG	5E, PLANT/SWITCH, END OF CORRIDOR	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136991 DP ABE EXTG 9KG	5W, NEW BLDG, PLANT RM WP5.88	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136992 DP ABE EXTG 9KG	5W, NEW BLDG, PLANT ROOM 3	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136993 DP ABE EXTG 9KG	5W, NEW BLDG OFFICE, PLANT ROOM 1	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136611 DP ABE EXTG 9KG	6C, LIFT FOYER, O/S PLANT RM	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136609 DP ABE EXTG 9KG	6C, WESTERN EXIT, TISSUE CULT 1	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136610 DP ABE EXTG 9KG	6E, O/S EAST PLANT, E6.52B	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136994 DP ABE EXTG 9KG	6W, NEW BLDG, PLANT ROOM 2	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136997 DP ABE EXTG 9KG	6W, NEW BLDG, PLANT ROOM 3	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136999 DP ABE EXTG 9KG	6W, NEW BLDG OFFICE, PLANT RM WP6.40	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003492566 DP ABE EXTG 9KG	7E, ONCOLOGY, O/S PLANT ROOM	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003137000 DP ABE EXTG 9KG	7W, NEW BLDG, W7.87	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003210474 DP ABE EXTG 9KG	8W, HHW PLANT ROOM, WP8.11 ENTRY	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG

SV no: XXXX  
Printed: XX/XX/2022

Maintenance performed in accordance with AS 1851 - 2005  
Hose Reel(s) without water flow defects listed above are deemed to have PASSED - with a minimum flow of 20 l/min (for 19mm hose) or 25 l/min (for 25mm hose) in accordance with the BCA & AS1851

a division of





# FIRE EQUIPMENT SERVICES

PO Box 3070, Nunawading, Vic 3131  
www.fes.com.au e: service@fes.com.au

ABN 28 598 558 561  
Tel 1300 855 163  
Fax 1300 655 511



## ESSENTIAL SAFETY MEASURES SERVICE REPORT

The Level of Performance and Frequency of Maintenance is as required by Essential Safety Measures Requirements

Service Visit:  
Completed Date:  
Site Details: **XXXX**

### SAMPLE REPORT

Work Performed By: XXX

Purchase Order: **PO# XXXX**

## COMPLETED WORK

Equipment Serviced	Location	Service Performed
0003060676 DP ABE EXTG 9KG	BASEMENT (W), NEW BLDG, BOTTM OF C/DOOR	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136986 DP ABE EXTG 9KG	BASEMENT (W), SWITCH RM, WB.34	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003210466 DP ABE EXTG 9KG	GR, CENTRAL, PLANT ROOM	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003210468 DP ABE EXTG 9KG	GR, SWITCH ROOM, MOBILE STATION	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003250529 DP ABE EXTG 9KG	HYDRAULIC P/R, WB.28, ENTRY	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003250530 DP ABE EXTG 9KG	MECHANICAL P/R, WB.29	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003250528 DP ABE EXTG 9KG	MECHANICAL P/R, WB.33	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0003136623 DP ABE EXTG 9KG	ROOF (W), NEW BLDG, WATER PUMP ROOM	DA0L1 L1 6-MTHLY SERVICE DP ABE EXTG
0000285054 FIRE BLANKET	6W, AT SHOWER, TISSUE CULTURE2	FB0L2 SERVICE FIRE BLANKET
0000523121 FIRE BLANKET	BASEMENT, RADIATION	FB0L2 SERVICE FIRE BLANKET
0000285056 FIRE BLANKET	GR, CENTRAL PLANT, GENERATOR ROOM	FB0L2 SERVICE FIRE BLANKET
0000862869 FIRE BLANKET 1.2Mx1.8M	1W, MEDIA PREP, OPP TONY OFFICE	FB0L2 SERVICE FIRE BLANKET
0000862867 FIRE BLANKET 1.2Mx1.8M	2W, NEW BLDG, DECONTAMINATION	FB0L2 SERVICE FIRE BLANKET
0000862866 FIRE BLANKET 1.2Mx1.8M	2W, NEW BLDG, SAFETY SHOWER	FB0L2 SERVICE FIRE BLANKET
0000862868 FIRE BLANKET 1.2Mx1.8M	2W, NEW BLDG, SAFETY SHOWER	FB0L2 SERVICE FIRE BLANKET
0000925327 FIRE BLANKET 1.2Mx1.8M	3C, CENTRAL LAB, OPP C3.74	FB0L2 SERVICE FIRE BLANKET
0003369687 FIRE BLANKET 1.2Mx1.8M	3C, OPP C3.52, AT EYE WASH	FB0L2 SERVICE FIRE BLANKET
0000925321 FIRE BLANKET 1.2Mx1.8M	3C, SAFETY SHOWER, C3.67	FB0L2 SERVICE FIRE BLANKET
0000925315 FIRE BLANKET 1.2Mx1.8M	3E, SAFETY SHOWER, WET LAB E3.24	FB0L2 SERVICE FIRE BLANKET
0000862870 FIRE BLANKET 1.2Mx1.8M	3W, NEW BLDG, SAFETY SHOWER	FB0L2 SERVICE FIRE BLANKET
0000862871 FIRE BLANKET 1.2Mx1.8M	3W, NEW BLDG, SAFETY SHOWER	FB0L2 SERVICE FIRE BLANKET
0000862872 FIRE BLANKET 1.2Mx1.8M	3W, NEW BLDG, SAFETY SHOWER	FB0L2 SERVICE FIRE BLANKET
0000862873 FIRE BLANKET 1.2Mx1.8M	3W, NEW BLDG, SAFETY SHOWER	FB0L2 SERVICE FIRE BLANKET
0000925311 FIRE BLANKET 1.2Mx1.8M	4C, RECIEPT/SEND OU, C4.02	FB0L2 SERVICE FIRE BLANKET
0003060727 FIRE BLANKET 1.2Mx1.8M	4E, SHOWER, COLD ROOM E4.72	FB0L2 SERVICE FIRE BLANKET
0003060726 FIRE BLANKET 1.2Mx1.8M	4E, SHOWER, TISSUE 2 E4.75	FB0L2 SERVICE FIRE BLANKET
0000862874 FIRE BLANKET 1.2Mx1.8M	4W, NEW BLDG, SAFETY SHOWER	FB0L2 SERVICE FIRE BLANKET
0000862875 FIRE BLANKET 1.2Mx1.8M	4W, NEW BLDG, SAFETY SHOWER	FB0L2 SERVICE FIRE BLANKET
0000862876 FIRE BLANKET 1.2Mx1.8M	4W, NEW BLDG, SAFETY SHOWER	FB0L2 SERVICE FIRE BLANKET
0000862877 FIRE BLANKET 1.2Mx1.8M	4W, NEW BLDG, SAFETY SHOWER	FB0L2 SERVICE FIRE BLANKET
0000925350 FIRE BLANKET 1.2Mx1.8M	5C, EAST EXIT, C5.59	FB0L2 SERVICE FIRE BLANKET
0003369688 FIRE BLANKET 1.2Mx1.8M	5C, INSTRUMENT ROOM, BESIDE LIFT	FB0L2 SERVICE FIRE BLANKET
0000925354 FIRE BLANKET 1.2Mx1.8M	5C, OPP C5.71	FB0L2 SERVICE FIRE BLANKET
0000925357 FIRE BLANKET 1.2Mx1.8M	5C, OPP C5.75	FB0L2 SERVICE FIRE BLANKET
0000925339 FIRE BLANKET 1.2Mx1.8M	5E, LAB, SAFETY SHOWER	FB0L2 SERVICE FIRE BLANKET
0003330431 FIRE BLANKET 1.2Mx1.8M	5E, NEW LAB, NEAR LIFT	FB0L2 SERVICE FIRE BLANKET
0003330433 FIRE BLANKET 1.2Mx1.8M	5E, NEW LAB, NEAR LIFT	FB0L2 SERVICE FIRE BLANKET
0003060744 FIRE BLANKET 1.2Mx1.8M	5E, WEST EXIT, COLD ROOM C5.72	FB0L2 SERVICE FIRE BLANKET
0000862878 FIRE BLANKET 1.2Mx1.8M	5W, NEW BLDG, SAFETY SHOWER	FB0L2 SERVICE FIRE BLANKET
0000862879 FIRE BLANKET 1.2Mx1.8M	5W, NEW BLDG, SAFETY SHOWER	FB0L2 SERVICE FIRE BLANKET
0000862880 FIRE BLANKET 1.2Mx1.8M	5W, NEW BLDG, SAFETY SHOWER	FB0L2 SERVICE FIRE BLANKET
0000862881 FIRE BLANKET 1.2Mx1.8M	5W, NEW BLDG, SAFETY SHOWER	FB0L2 SERVICE FIRE BLANKET
0003060758 FIRE BLANKET 1.2Mx1.8M	6, EQUIPMENT ROOM, C6.82	FB0L2 SERVICE FIRE BLANKET

SV no: XXXX  
Printed: XX/XX/2022

Maintenance performed in accordance with AS 1851 - 2005  
Hose Reel(s) without water flow defects listed above are deemed to have PASSED - with a minimum flow of 20 l/min (for 19mm hose) or 25 l/min (for 25mm hose) in accordance with the BCA & AS1851

a division of





# FIRE EQUIPMENT SERVICES

PO Box 3070, Nunawading, Vic 3131  
www.fes.com.au e: service@fes.com.au

ABN 28 598 558 561  
Tel 1300 855 163  
Fax 1300 655 511



## ESSENTIAL SAFETY MEASURES SERVICE REPORT

The Level of Performance and Frequency of Maintenance is as required by Essential Safety Measures Requirements

Service Visit:  
Completed Date:  
Site Details: XXXX

### SAMPLE REPORT

Work Performed By: XXX

Purchase Order: PO# XXXX

## COMPLETED WORK

Equipment Serviced	Location	Service Performed
0003060662 FIRE BLANKET 1.2Mx1.8M	6C, SHOWER, OPPOSITE C6.75	FB0L2 SERVICE FIRE BLANKET
0000862882 FIRE BLANKET 1.2Mx1.8M	6W, NEW BLDG, SAFETY SHOWER	FB0L2 SERVICE FIRE BLANKET
0000862883 FIRE BLANKET 1.2Mx1.8M	6W, NEW BLDG, SAFETY SHOWER	FB0L2 SERVICE FIRE BLANKET
0000862884 FIRE BLANKET 1.2Mx1.8M	6W, NEW BLDG, SAFETY SHOWER	FB0L2 SERVICE FIRE BLANKET
0000862885 FIRE BLANKET 1.2Mx1.8M	6W, NEW BLDG, SAFETY SHOWER	FB0L2 SERVICE FIRE BLANKET
0000862886 FIRE BLANKET 1.2Mx1.8M	7W, NEW BLDG, SAFETY SHOWER	FB0L2 SERVICE FIRE BLANKET
0000862887 FIRE BLANKET 1.2Mx1.8M	7W, NEW BLDG, SAFETY SHOWER	FB0L2 SERVICE FIRE BLANKET
0000862888 FIRE BLANKET 1.2Mx1.8M	7W, NEW BLDG, SAFETY SHOWER	FB0L2 SERVICE FIRE BLANKET
0000862889 FIRE BLANKET 1.2Mx1.8M	7W, NEW BLDG, SAFETY SHOWER	FB0L2 SERVICE FIRE BLANKET
0003060688 FIRE BLANKET 1M x1M	1E, COMMUNICAIONS, BEHIND RECEPTION	FB0L2 SERVICE FIRE BLANKET
0003060774 FIRE BLANKET 1M x1M	7W, TEA ROOM, KITCHEN	FB0L2 SERVICE FIRE BLANKET
0000115594 HOSE REEL	1C, LIQUID NITROGEN, WEST STAIRS	HR0L2 L2 ANNUAL SERVICE HOSE REEL
0000115607 HOSE REEL	1E, RECEPTION	HR0L2 L2 ANNUAL SERVICE HOSE REEL
0003060665 HOSE REEL	1W, BESIDE WASH RM, LIFT FOYER	HR0L2 L2 ANNUAL SERVICE HOSE REEL
0003060675 HOSE REEL	1W, NEW BLDG, O/SIDE ENGIN/NG	HR0L2 L2 ANNUAL SERVICE HOSE REEL
0003060652 HOSE REEL	1W, OPPOSITE, TONY'S OFFICE	HR0L2 L2 ANNUAL SERVICE HOSE REEL
0000115613 HOSE REEL	2C, LIFT FOYER, AT GLASS DOORS	HR0L2 L2 ANNUAL SERVICE HOSE REEL
0000115618 HOSE REEL	2C, WEST EXIT	HR0L2 L2 ANNUAL SERVICE HOSE REEL
0000388250 HOSE REEL	2E, HR, EAST EXIT DOOR	HR0L2 L2 ANNUAL SERVICE HOSE REEL
0000915004 HOSE REEL	2W, NEW BLDG, DECONTAMINATION	HR0L2 L2 ANNUAL SERVICE HOSE REEL
0000915016 HOSE REEL	2W, NEW BLDG, O/SIDE W2.61	HR0L2 L2 ANNUAL SERVICE HOSE REEL
0003060789 HOSE REEL	2W, W2.51, FOYER	HR0L2 L2 ANNUAL SERVICE HOSE REEL
0000115632 HOSE REEL	3C, LIFT FOYER	HR0L2 L2 ANNUAL SERVICE HOSE REEL
0000115622 HOSE REEL	3C, WEST EXIT, OPP PLANT ROOM	HR0L2 L2 ANNUAL SERVICE HOSE REEL
0000115640 HOSE REEL	3E, EAST EXIT, OPP PLANT ROOM	HR0L2 L2 ANNUAL SERVICE HOSE REEL
0000915042 HOSE REEL	3W, NEW BLDG, EAST ENTRY	HR0L2 L2 ANNUAL SERVICE HOSE REEL
0000915032 HOSE REEL	3W, NEW BLDG, WEST EXIT	HR0L2 L2 ANNUAL SERVICE HOSE REEL
0000915029 HOSE REEL	3W, NEW BLDG OFFICE, EAST ENTRY	HR0L2 L2 ANNUAL SERVICE HOSE REEL
0000915023 HOSE REEL	3W, NEW BLDG OFFICE, WEST EXIT	HR0L2 L2 ANNUAL SERVICE HOSE REEL
0000115652 HOSE REEL	4C, LIFT FOYER	HR0L2 L2 ANNUAL SERVICE HOSE REEL
0000115666 HOSE REEL	4C, WEST EXIT	HR0L1 L1 6-MTHLY SERVICE HOSE REEL
0000115644 HOSE REEL	4E, EAST STAIRS, M/SCOPE E4.76	HR0L2 L2 ANNUAL SERVICE HOSE REEL
0000915061 HOSE REEL	4W, NEW BLDG, EAST ENTRY	HR0L1 L1 6-MTHLY SERVICE HOSE REEL
0000915052 HOSE REEL	4W, NEW BLDG, WEST EXIT	HR0L2 L2 ANNUAL SERVICE HOSE REEL
0000915048 HOSE REEL	4W, NEW BLDG OFFICE, EAST ENTRY	HR0L2 L2 ANNUAL SERVICE HOSE REEL
0000915043 HOSE REEL	4W, WEST EXIT, AT LOCKERS	HR0L2 L2 ANNUAL SERVICE HOSE REEL
0000115689 HOSE REEL	5C, LIFT FOYER	HR0L1 L1 6-MTHLY SERVICE HOSE REEL
0000115669 HOSE REEL	5C, WEST EXIT, CENTRAL STAIRS	HR0L1 L1 6-MTHLY SERVICE HOSE REEL
0000115682 HOSE REEL	5E, EAST EXIT	HR0L1 L1 6-MTHLY SERVICE HOSE REEL
0000915083 HOSE REEL	5W, NEW BLDG, EAST ENTRY	HR0L2 L2 ANNUAL SERVICE HOSE REEL
0000915075 HOSE REEL	5W, NEW BLDG, WEST EXIT	HR0L2 L2 ANNUAL SERVICE HOSE REEL
0000915069 HOSE REEL	5W, NEW BLDG OFFICE, EAST ENTRY	HR0L2 L2 ANNUAL SERVICE HOSE REEL
0000915064 HOSE REEL	5W, NEW BLDG OFFICE, WEST EXIT	HR0L2 L2 ANNUAL SERVICE HOSE REEL
0003060752 HOSE REEL	6, LIFT FOYER	HR0L2 L2 ANNUAL SERVICE HOSE REEL

SV no: XXXX  
Printed: XX/XX/2022

Maintenance performed in accordance with AS 1851 - 2005  
Hose Reel(s) without water flow defects listed above are deemed to have PASSED - with a minimum flow of 20 l/min (for 19mm hose) or 25 l/min (for 25mm hose) in accordance with the BCA & AS1851

a division of







# FIRE EQUIPMENT SERVICES

PO Box 3070, Nunawading, Vic 3131  
www.fes.com.au e: service@fes.com.au

ABN 28 598 558 561  
Tel 1300 855 163  
Fax 1300 655 511



## ESSENTIAL SAFETY MEASURES SERVICE REPORT

The Level of Performance and Frequency of Maintenance is as required by Essential Safety Measures Requirements

Service Visit:  
Completed Date:  
Site Details: **XXXX**

### SAMPLE REPORT

Work Performed By: XXX

Purchase Order: **PO# XXXX**

## COMPLETED WORK

Equipment Serviced	Location	Service Performed
0000115713 HOSE REEL	6C, CENTRAL STAIRS, TISSUE CULT 1	HR0L2 L2 ANNUAL SERVICE HOSE REEL
0000115698 HOSE REEL	6E, EAST EXIT, OPP PLANT ROOM	HR0L2 L2 ANNUAL SERVICE HOSE REEL
0000915106 HOSE REEL	6W, NEW BLDG, EAST ENTRY	HR0L2 L2 ANNUAL SERVICE HOSE REEL
0000915096 HOSE REEL	6W, NEW BLDG, WEST EXIT	HR0L2 L2 ANNUAL SERVICE HOSE REEL
0000915091 HOSE REEL	6W, NEW BLDG OFFICE, EAST LOUNGE	HR0L2 L2 ANNUAL SERVICE HOSE REEL
0000915088 HOSE REEL	6W, NEW BLDG OFFICE, WEST EXIT	HR0L2 L2 ANNUAL SERVICE HOSE REEL
0000115724 HOSE REEL	7E, ONCOLOGY, OPP PLANT ROOM	HR0L2 L2 ANNUAL SERVICE HOSE REEL
0000915157 HOSE REEL	7W, NEW BLDG, EAST EXIT	HR0L2 L2 ANNUAL SERVICE HOSE REEL
0000915122 HOSE REEL	7W, NEW BLDG, WEST EXIT	HR0L2 L2 ANNUAL SERVICE HOSE REEL
0000915114 HOSE REEL	7W, NEW BLDG OFFICE, EAST ENTRY	HR0L2 L2 ANNUAL SERVICE HOSE REEL
0000915109 HOSE REEL	7W, NEW BLDG OFFICE, WEST EXIT	HR0L2 L2 ANNUAL SERVICE HOSE REEL
0000115716 HOSE REEL	7W, TEA ROOM	HR0L2 L2 ANNUAL SERVICE HOSE REEL
0003060768 HOSE REEL	7W, TEA ROOM, OPP THEATRE	HR0L2 L2 ANNUAL SERVICE HOSE REEL
0000115746 HOSE REEL	8C, AT ENTRY	HR0L2 L2 ANNUAL SERVICE HOSE REEL
0000115726 HOSE REEL	8C, EAST PLANT RM, EAST EXIT	HR0L2 L2 ANNUAL SERVICE HOSE REEL
0000115744 HOSE REEL	8C, MIDDLE	HR0L2 L2 ANNUAL SERVICE HOSE REEL
0000915151 HOSE REEL	BASE (W), NEW BLDG, BOTTM OF C/DOOR	HR0L2 L2 ANNUAL SERVICE HOSE REEL
0000915154 HOSE REEL	BASE (W), NEW BLDG, TOP OF RAMP	HR0L2 L2 ANNUAL SERVICE HOSE REEL
0003060686 HOSE REEL	BASEMENT, LIFT FOYER, CARPARK	HR0L2 L2 ANNUAL SERVICE HOSE REEL
0000115583 HOSE REEL	BASEMENT, OPP RADIATION, CORRIDOR	HR0L2 L2 ANNUAL SERVICE HOSE REEL
0000115591 HOSE REEL	GR, CENTRAL, PLANT ROOM	HR0L2 L2 ANNUAL SERVICE HOSE REEL
0000915138 HOSE REEL	ROOF (W), NEW BLDG	HR0L2 L2 ANNUAL SERVICE HOSE REEL
0000915140 HOSE REEL	ROOF (W), NEW BLDG, BSIDE BOILER RM	HR0L2 L2 ANNUAL SERVICE HOSE REEL
0000915137 HOSE REEL	ROOF (W), NEW BLDG, WATER PUMP RM	HR0L2 L2 ANNUAL SERVICE HOSE REEL
0003250526 SOLBERG FM EXTG 9L	BASEMENT (W), MECHANICAL P/R, WB.29	SO0L1 L1 6-MTH SERVICE SPF/SOLB EXTG
0003396183 SPF/ATC EXTG 9L	1C, OPP CRYOGENICS, C1.68 CORRIDOR	ST0L1 L1 6-MTH SERV SPF/ATC EXTG
0003396184 SPF/ATC EXTG 9L	1W, DANGEROUS GOODS, W1.58	ST0L1 L1 6-MTH SERV SPF/ATC EXTG
0003060772 SPW EXTG 9L	7W, TEA ROOM	SW0L1 L1 6-MTHLY SERV SPW EXTG
0003060778 SPW EXTG 9L	7W, TEA ROOM, AT RUBBISH BINS	SW0L1 L1 6-MTHLY SERV SPW EXTG
0003060777 SPW EXTG 9L	7W, TEA ROOM, RECESSED	SW0L1 L1 6-MTHLY SERV SPW EXTG
0003060767 SPW EXTG 9L	7W, TOP OF STAIRS, OPP THEATRE	SW0L1 L1 6-MTHLY SERV SPW EXTG



Customer Signature

SV no: XXXX  
Printed: XX/XX/2022

Maintenance performed in accordance with AS 1851 - 2005  
Hose Reel(s) without water flow defects listed above are deemed to have PASSED - with a minimum flow of 20 l/min (for 19mm hose) or 25 l/min (for 25mm hose) in accordance with the BCA & AS1851

a division of







# FIRE EQUIPMENT SERVICES

PO Box 3070, Nunawading, Vic 3131  
www.fes.com.au e: service@fes.com.au

ABN 28 598 558 561  
Tel 1300 855 163  
Fax 1300 655 511



## ESSENTIAL SAFETY MEASURES SERVICE REPORT

The Level of Performance and Frequency of Maintenance is as required by Essential Safety Measures Requirements

Service Visit:  
Completed Date:  
Site Details: **XXXX**

**SAMPLE REPORT**

Work Performed By: XXX

Purchase Order: **PO# XXXX**

This report has been completed and signed by: XXXX

*This document was digitally signed on XX/XX/2022*

SV no: XXXX  
Printed: 20/09/2022

Maintenance performed in accordance with AS 1851 - 2005  
Hose Reel(s) without water flow defects listed above are deemed to have PASSED - with a minimum flow of 20 l/min (for 19mm hose) or 25 l/min (for 25mm hose) in accordance with the BCA & AS1851

a division of

