

Property:

TRAINING Training site
3-9 Yarra Street,
Abbotsford, VIC 3067

Client:

Training client

Task:

T-04752

Authorisation ref:

Purchase Order 1234

Issued by:

Tara Papapetrou
8th April 2024

Performed Date:

8th April 2024

Scope of Works

Fire Extinguishers: Portable & Wheeled (AS 1851:2012 Section 10): Annual (3)

0	Critical Defects	A defect that renders a system inoperative.
1	Non-critical Defects	A system impairment not likely to critically affect the operation of the system.
0	Non-conformances	Missing information or incorrect feature that does not affect the system operation.
0	Recommendations	A modification suggested to improve the system performance.
0	Informational Notes	Detailed advice or general comment.

Items requiring attention

Unable to gain access

Asset	Description	Resolution
003 - Portable: DCP (ABE) 4.5kg Remark ID:59716 SeverityNon-critical defect Status: Fail	5-yearly scheduled pressure test due	5 year pressure test completed

Maintenance

Asset	Status
003 - Portable: DCP (ABE) 4.5kg	FAIL
002 - Portable: (AFFF) Foam 9.0lt	PASS
001 - Portable: (AFFF) Foam 9.0lt	PASS

Signoff

Maintenance has been carried out in accordance with current regulations.